

1   **Supporting Information for**  
2   **Temporal Trends of Halogenated Flame Retardants in the Atmosphere**  
3   **of the Canadian Great Lakes Basin (2005-2014)**

4   Chubashini Shunthirasingham, Nick Alexandrou, Kenneth A. Brice, Ky Su, Helena Dryfhout-Clark, Cecilia  
5   Shin, Richard Park, Artur Pajda, Ronald Noronha, Hayley Hung<sup>\*</sup>

6   Air Quality Processes Research Section, Environment and Climate Change Canada, 4905 Dufferin St, ON,  
7   M3H 5T4 Canada

8

9   **Table of Content**

		<b>Page</b>
Section S1	Sample Collection, Analysis Methods and Data Management	S2
Section S2	Ratios between the dominant PBDE congeners (BDE-47 and -99) and <i>anti</i> - DDC-CO and total DDC-CO	S4
Section S3	Gas-Particle Partitioning of HFRs	S5
Table S1	Annual mean and standard deviation for field and laboratory blanks	S7
Table S2	% Breakthrough for very volatile HFRs	S20
Table S3	Concentrations of halogenated flame retardants at three sampling sites in the Canadian Great Lakes Basin	S21
Table S4	Pearson correlation coefficients among the primary components of the Penta BDE formulations at Point Petre, Burnt Island and Egbert.	S35
Table S5	Ratios between BDE-47 and -99, BDE-99 and -100 and <i>anti</i> -DDC-CO and total DDC-CO in Great Lakes air	S36
Table S6	Regression results from the one-parameter non-linear model	S37
Table S7	First order apparent halflives ( $t_{1/2}$ ) of halogenated flame retardants at the three Canadian Great Lakes sites.	S40
Figure S1	Relative abundance of non-PBDE HFRs at Point Petre and Burnt Island.	S41
Figure S2	Seasonal profiles of air concentrations of PBDEs and ambient temperature at Burnt Island.	S42
Figure S3	Seasonal profiles of air concentrations of non-PBDE HFRs and ambient temperature at Burnt Island.	S43
Figure S4	Seasonal cycles, trends and measurements of BDE-49, -100, -153 and -154 at Burnt Island and Point Petre	S44
Text	Literature Cited	S45

10

---

\*Corresponding author contact: +1-416-739-5944, Hayley.Hung@canada.ca

11      **Section S1. Sample Collection, Analysis Methods and Data Management**

12      S1.1 Air Sample Collection

13      Air was pulled through a General Metal Works PS-1 high volume sampler at ~0.24 m<sup>3</sup> min<sup>-1</sup>, for a total  
14      volume of about 350 m<sup>3</sup> over a 24-hour sampling period. Particles were collected on a prebaked (400 °C)  
15      10.2 cm diameter glass fiber filter (GFF, Gelman A/E Microfiber) and vapor phase organic pollutants were  
16      collected on a pre-cleaned polyurethane foam (PUF) (7.5 cm length x 6.2 cm diameter; PUF, Pacwill  
17      Environmental) plug.

18      S1.2 Air Sample Analysis

19      Air samples were analyzed in the Organics Analysis Laboratory (OAL), Environment and Climate Change  
20      Canada, Toronto, ON, Canada. The PUF plugs were Soxhlet extracted using 475 mL hexane for 24 hour.  
21      The PUF extracts were dried using pre-cleaned anhydrous sodium sulfate, reduced to 2 mL in iso-octane  
22      keeper using a Zymark/Biotage Turbovap 500 system at 38 °C. The PUF extracts were divided into 2  
23      aliquots of 1 mL each. The GFFs were extracted with a Dionex ASE200 using a hexane/acetone mixture  
24      (7:3), 2000 psi, 100 °C, 5 minute static cycle, 3 cycles per sample, 150% flush volume, 60 second purge  
25      with UHP nitrogen. The GFF extracts were reduced to 1 mL in iso-octane keeper using a Biotage  
26      Turbovap 200 system at 38 °C under a nitrogen pressure setting of 7 psi. The GFF extracts were not  
27      dried prior to volume reduction. For PBDE and non-BDE FR analysis, one PUF aliquot and the GFF extract  
28      were cleaned separately using silica columns on a Microlab 4000 automated SPE system with 6 mL of  
29      dichloromethane to remove interferences. All the SPE extracts were concentrated on the  
30      Zymark/Biotage Turbovap 200 system at 38 °C, a nitrogen pressure setting of 6 psi, with acetonitrile  
31      keeper to 0.5mL then accurately adjusted to 1 mL.

32      A 15 m x 0.25 mm i.d. x 0.10 µm film thickness Restek Rtx-1614 column was used with the GC-ECD  
33      (Agilent 6890) for determination of BDE-209 and DBDPE. The oven temperature used was 100 °C for 1  
34      min, 25°C/min to 200°C then 4.25°C/min to 315°C and hold for 3 min. Ultra high purity (UHP) He  
35      (Praxair) was used as carrier gas in constant-flow mode at a column flow-rate of approximately 1.2  
36      mL/min. Pulsed splitless-mode injections of 1 µL with pulse pressure of 30 psi for 1.05 min (purge on at  
37      1.0 min) were made using an autosampler/autoinjector system (Agilent 7683B series). Injection port and  
38      detector were held at 250°C and 350°C respectively. ECD make-up gas was UHP N<sub>2</sub> (Praxair) set at  
39      constant flow of 30 mL/min. Data files were manually integrated and processed using external standard  
40      methods for identification and quantification.

41      Gas chromatography electron capture negative ion mass spectrometry (GC-ECNIMS) was used to provide  
42      confirmatory analysis of processed sample fractions for all target analytes, except for BDE-209 and  
43      DBDPE. An Agilent MS-Engine system was used for samples up to and including the 2008 sampling  
44      year. An Agilent 5975 MS system was used for samples from 2009 onwards. 2009 samples were  
45      analysed using both the Agilent MS-Engine and the Agilent 5975 MS. Data from both methods were  
46      compared and good agreement was found. The coefficient of variance between the two methods ranged  
47      from 0 to 25 %.

48      The MS-Engine system instrumentation consisted of an HP5890 GC interfaced to an HP5989B MS (MS-  
49      Engine) mass spectrometer, equipped with negative ion chemical ionization capability and high-energy

50 dynode (HED) detector. Gas chromatographic conditions consisted of a heated splitless/split injection  
51 port (Merlin micro-seal; deactivated, borosilicate glass, single tapered liner) at a temperature of 200<sup>0</sup>C; a  
52 30 m x 0.25 mm i.d. x 0.25 µm film thickness DB5 column (J&W Scientific) was used (80<sup>0</sup>C for 2 min,  
53 15<sup>0</sup>C/min to 160<sup>0</sup>C then 2.5<sup>0</sup>C/min to 260<sup>0</sup>C and hold for 62 minutes), trace analytical grade (TAG) He  
54 (Praxair) as carrier gas in constant-pressure mode, at an initial column flow-rate of approximately 1.3  
55 mL/min. Splitless-mode injections of 2 µL (purge on at 2.0 min) were made using an  
56 autosampler/autoinjector system (HP 7673 series). Mass spectrometer operational conditions were:  
57 transfer line, 275<sup>0</sup>C; source, 150<sup>0</sup>C; quadrupole, 100<sup>0</sup>C; reagent gas, UHP methane (Praxair) at 2.0 torr;  
58 electron energy, 230 eV; emission current, 300 mA; electron multiplier voltage (typical tune plus 500V),  
59 HED voltage, 10,000 V. Selected ion mode (SIM) was employed to maximize sensitivity for PBDEs, with  
60 just two ions being monitored: m/e at 79 for quantitation (Q) and m/e at 81 for confirmation (C) with  
61 dwell time set at 100 ms. At appropriate points in the chromatogram, representative ions for the  
62 retention markers TBB (314) and OCN (404) were monitored. Overall system control, data acquisition  
63 and data reduction was conducted with an HP59944C MS ChemSystem (UNIX). Data files were manually  
64 integrated and processed using external standard methods for identification and quantification.

65 The Agilent 5975 MS system instrumentation consisted of an Agilent 7890A GC interfaced to an Agilent  
66 5975 MSD equipped with negative ion capability. GC conditions consisted of a heated splitless/split  
67 injection port at a temperature of 200<sup>0</sup>C; a 30 m × 0.25 mm i.d. × 0.25 µm film thickness DB5 column  
68 (J&W Scientific) was used (80<sup>0</sup>C for 2 min, 15<sup>0</sup>C/min to 160<sup>0</sup>C then 2.5<sup>0</sup>C/min to 260<sup>0</sup>C for 4 min then  
69 2.5<sup>0</sup>C/min to 285<sup>0</sup>C and hold for 15 min). Pulsed splitless-mode injections of 1.5 µL were made using an  
70 autosampler/autoinjector system (Agilent 7683 series). An injector pulse pressure of 35 psi was used  
71 until 1.5 mins. A purge flow to split vent of 50 mL/min at 1.0 min was utilized. MS operational  
72 conditions were: transfer line, 280<sup>0</sup>C; source, 150<sup>0</sup>C; quadrupole, 150<sup>0</sup>C; reagent gas, UHP methane  
73 (Praxair) a flow rate of 40 % (the value is a percentage of maximum flow rate). Selected ion mode (SIM)  
74 was employed to maximize sensitivity for PBDEs and BFRs, with the following ions being monitored: m/e  
75 at 79, 81, 160, 237, 291, 404, 464, 551.5 and 652. Overall system control, data acquisition and data  
76 reduction was conducted with an Enhanced ChemStation and data files were manually integrated and  
77 processed using external standard methods for identification and quantification.

### 78 S1.3 Air Sample Blanks and Recoveries

79 Six field blanks were collected each year at every site by placing a sampler head with a PUF and a GFF in  
80 the HiVol sampler and immediately removing without drawing air through the sampler. Laboratory and  
81 field blanks were processed in the same way as the samples to determine the contamination introduced  
82 during extraction and clean-up; and by handling, shipping and storage, respectively. Laboratory blanks  
83 were included with every second batch of samples. A blank clean PUF and a blank clean GFF were spiked  
84 with 1.00 mL of halogenated flame retardant (HFR) standard (10 pg/µL for each HFR), and processed as  
85 air samples. For each sample batch, a silica column was spiked with 1.00 mL of the same HFR standard  
86 and taken through the SPE cleanup procedure.

### 87 S1.4 Data Management

88 Research Data Management and Quality Control System<sup>TM</sup> (RDMQ<sup>TM</sup>) is an interactive SAS-based system  
89 which provides a means of evaluating and flagging data (Sukloff et al., 1995). The RDMQ<sup>TM</sup> evaluates raw

90 data by assigning flags based on sample quality (duration and volume of sample, meteorological  
91 conditions, presence of unusual anthropological or natural conditions at the site, and adherence to field  
92 and laboratory protocols). Data are flagged and may be invalidated if they are of low sample quality.  
93 Statistical analysis of field blank concentrations was used to assess for background method  
94 concentrations and to determine method detection limits. Statistical analysis of samples were used to  
95 assess the percentage of quantifiable samples and to identify and investigate outliers. The data were also  
96 manually reviewed and identified for any anomalies present by plotting time series of ambient  
97 concentrations as well as quality indicators such as blank levels and method detection limits. Finally,  
98 summaries of quality control activities such as the analysis of common reference standards and matrix  
99 spikes were used to provide information about the quality of the final dataset. The summarized data  
100 were approved by the data management team and the principal investigator. The raw data have  
101 undergone several evaluation steps before being accepted as valid data.

102 **Section S2. Ratios between the dominant PBDE congeners (BDE-47 and -99) and anti- DDC-CO and total**  
103 **DDC-CO**

104 BDE-47, -99 and -100 are the main components of the commercial Penta-BDE formulations, with BDE-47  
105 accounting for 38-43 %, BDE-99 account for 45-49 % and BDE-100 accounting for 7.8-13% of the  
106 product<sup>1</sup>. Pearson correlation analysis was performed on the concentrations of the main components of  
107 Penta-BDE technical mixture to determine whether they were from the same source. Significant  
108 correlations were observed among BDE-47, -99 and -100 (Table S4), suggesting that they likely came  
109 from similar sources. The yearly average ratio of BDE-47/-99 in the GLB air samples ranged from 0.9 to  
110 3.3 (Table S5), which are higher than the ratios measured in the commercial Penta-BDE mixtures (DE-71  
111 = 0.79 and Bromkal 70-5DE = 0.96), whereas the yearly average ratios of BDE-99/-100 (ranged from 3.5  
112 to 6.1) are similar to those ratios measured in the Penta-BDE formulations (DE-71 = 3.7 and Bromkal 70-  
113 5DE = 5.7). Su et al.<sup>2</sup> also reported similar BDE-47/-99 and BDE-99/-100 ratios in the air samples collected  
114 at Point Petre. Photo-oxidation during LRAT can modify the composition of these mixtures; the photo-  
115 degradation half-lives of BDE-47 and -100 are longer than that of BDE99<sup>3</sup>. Accordingly, high BDE-47/-99  
116 and low BDE-99/-100 ratios indicate that BDE99 photo-degrades during LRAT. In the GLB air samples,  
117 only high ratios of BDE-47/-99 were observed. BDE-47 is a more volatile compound than BDE-99<sup>4</sup>; our  
118 results (high BDE-47/-99 ratios) indicate that BDE-47 must be coming from secondary emissions (e.g.  
119 from soils) or primary emissions (e.g. from BDE treated products).

120 The *anti*-DDC-CO fractional abundance ( $f_{anti}$ ) can be used to assess the fate and distribution of DDC-CO in  
121 the environment. The  $f_{anti}$  was calculated as the ratio of the concentration of the *anti*-DDC-CO isomer  
122 divided by the sum of the concentrations of the *anti*- plus *syn*-DDC-CO isomers in the gas plus particle  
123 phase. Commercial DDC-CO product from OxyChem contains about 75 % *anti*-DDC-CO and 25 % *syn*-DP,  
124 giving a  $f_{anti}$  value of 0.75<sup>5</sup>. The annual average  $f_{anti}$  values at Point Petre and Burnt Island are listed in  
125 Table S5. The values  $f_{anti}$  range from 0.67 to 0.84, which are similar to that for the commercial product.  
126 This suggests that both DDC-CO isomers have similar atmospheric persistence and that no obvious  
127 stereo-selective process has occurred during atmospheric transport. This is consistent with the study by  
128 Venier and Hites<sup>6</sup>, who reported a similar fate for these two isomers in the atmosphere. However,  
129 Salamova et al.<sup>7</sup> observed a decrease in  $f_{anti}$  in particle phase with increasing distance from the source  
130 area, indicating that *syn*-DDC-CO is more stable toward photo-degradation during LRAT.

131    **Section S3. Gas-Particle Partitioning of HFRs**

132    The fate, transport and removal of semi-volatile organic compounds (SVOCs) from the atmosphere via  
133    dry and wet deposition are influenced by their gas-particle partitioning. The degree of particle sorption is  
134    related to the vapor pressure of a chemical, e.g. low volatility compounds such as BDE-209 and DBDPE  
135    present mainly in particulate phase. The *G/P* partitioning behavior of SVOCs is defined either by the  
136    particle/gas partition coefficient,  $K_p$  ( $\text{m}^3 \text{ air } \cdot \text{ug}^{-1}$  of particles) or the fraction of the total concentration of  
137    a SVOC in the atmosphere sorbed to particles,  $\phi$ <sup>8</sup>. The  $\phi$  correlates strongly with sub-cooled liquid vapor  
138    pressure,  $P_L$  (Pa). One- or two- parameter non-linear model can be used to regress between  $\phi$  and  $P_L$ . Su  
139    et al.<sup>8</sup> suggested that regression between  $\phi$  and  $P_L$  by the one- and two-parameter non-linear models are  
140    comparable, thus the one-parameter non-linear model (Junge-Pankow model)<sup>9</sup> as show in Eq.1 was used  
141    to fit gas/particle partitioning of PBDEs from different sampling events at Point Petre in this study.

142                          
$$\phi = A / (A + P_L) \quad (1)$$

143    where  $A$  is a fitting parameter. The final adjusted  $P_L$  values at 25 °C for BDE-28, BDE-47, BDE-99, BDE-100  
144    and BDE-153 are reported in Wania and Dugani<sup>4</sup> but are not available for BDE-17, BDE-49, BDE-66, BDE-  
145    85, BDE-138, BDE-154, BDE-183 and BDE-209. Thus, their  $P_L$  values at 25 °C were derived from the  
146    correlation between  $P_L$  and Le Bas Molar volume<sup>4</sup>. The  $P_L$  values for the PBDEs at the ambient  
147    temperature of the sampling period at Point Petre were calculated using final adjusted  $P_L$  and  $\Delta H_{vap}$   
148    data<sup>10</sup>.

149    The one-parameter non-linear regression was performed for 114 sampling events, where each sampling  
150    event contained 6 or more pairs of  $\phi$  and  $P_L$ . The regression results are reported in Table S6. The  
151    correlation coefficient,  $R^2$ , ranged between 0.40 and 0.99, except for 15 sampling events. The fitting  
152    parameter  $A$  ranged from  $1.5 \times 10^{-9}$  to  $3.6 \times 10^{-5}$ .  $A$  is related to partitioning capacity of particles for  
153    SVOCs. Adsorption onto the particle surface<sup>11</sup> and absorption into the organic matter of the particles<sup>12</sup>  
154    are two mechanisms, which have been used to explain the gas/particle partitioning behavior of SVOCs. In  
155    the case of adsorptive mechanism,  $A$  is related to particle surface area  $\theta$ , whereas in the case of  
156    absorption mechanism,  $A$  is determined from the concentrations of the total suspended particles *TSP*  
157    and organic matter content of particles  $f_{OM}$ . The  $\theta$ , *TSP* and  $f_{OM}$  can vary widely in background, urban and  
158    rural air<sup>8</sup>. We observed a large variability in the  $A$  values in this study which is likely due to the different  
159    sorptive properties of the particles as a result of their different origins to the sampling sites and also the  
160    *TSP*.

161

162

163

164

165

166

167

168 **Table S1.** Annual mean and standard deviation for field and laboratory blank

169 **Part1.** Burnt Island from 2005 to 2013

	<b>Field Blank GFF (Average ± SD)</b>	<b>Field blank PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
<b>Non-PBDE HFRs</b>			
<b>anti-DDC-CO</b>			
2008			
2009		0.024 ± 0.033	
2010			
2011			
2012			0.0048 ± 0.0118
2013			
<b>syn-DDC-CO</b>			
2008			
2009			0.0048 ± 0.012
2010			
2011			0.0033 ± 0.0082
2012			
2013			
<b>TBP-AE</b>			
2009		0.059 ± 0.042	
2010		0.047 ± 0.034	0.0059 ± 0.0088
2011		0.095 ± 0.084	0.010 ± 0.022
2012	0.012 ± 0.016	0.057 ± 0.027	0.0076 ± 0.017
2013	0.012 ± 0.016		
<b>TBP-BAE</b>			
2009			
2010			
2011			
2012			
2013			
<b>BTBPE</b>			
2009			
2010			0.0051 ± 0.018
2011			0.010 ± 0.025
2012			
2013			
<b>DBDPE</b>			
2009			
2010			
2011			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2012	0.021 ± 0.042		
2013			
<b>DPTE</b>			
2009			
2010			
2011		0.018 ± 0.012	
2012			
2013			
<b>HBBz</b>			
2009		0.024 ± 0.033	
2010	0.042 ± 0.016	0.094 ± 0.023	0.040 ± 0.029
2011		0.018 ± 0.012	0.0049 ± 0.012
2012		0.019 ± 0.022	
2013			
<b>HBCDD</b>			
2009			
2010			
2011			
2012			
2013			
<b>PBEB</b>			
2009			
2010			
2011		0.0012 ± 0.0024	
2012			
2013			
<b>PBT</b>			
2009			
2010	0.024 ± 0.013	0.046 ± 0.0072	0.028 ± 0.016
2011		0.0058 ± 0.011	0.0035 ± 0.0085
2012		0.0074 ± 0.0086	0.0040 ± 0.0070
2013			
<b>EH-TBB</b>			
2009			
2010			
2011			
2012			0.043 ± 0.15
2013			
<b>PBDEs</b>			
<b>BDE-17</b>			
2005			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
<b>BDE-28</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011		0.013 ± 0.026	
2012		0.020 ± 0.017	
2013			
<b>BDE-47</b>			
2005		1.2 ± 0.14	0.25 ± 0.26
2006		1.1 ± 0.073	0.18 ± 0.22
2007		0.68 ± 0.29	0.090 ± 0.17
2008		0.93 ± 0.57	0.021 ± 0.069
2009		0.68 ± 0.28	0.0839 ± 0.11
2010		0.55 ± 0.092	0.12 ± 0.12
2011		0.22 ± 0.25	0.082 ± 0.072
2012		0.68 ± 0.094	0.31 ± 0.23
2013		0.33 ± 0.00	
<b>BDE-49</b>			
2005			
2006			
2007			
2008			
2009			
2010		0.013 ± 0.018	
2011		0.011 ± 0.022	
2012			
2013			
<b>BDE-66</b>			
2005			
2006			
2007			
2008			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2009			
2010			
2011			
2012			
2013			
<b>BDE-71</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
<b>BDE-85</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
<b>BDE-99</b>			
2005		1.1 ± 0.38	0.15 ± 0.20
2006		1.2 ± 0.44	0.20 ± 0.22
2007		0.39 ± 0.17	
2008		0.77 ± 0.56	
2009		0.27 ± 0.20	0.069 ± 0.14
2010		0.54 ± 0.16	0.15 ± 0.16
2011		0.34 ± 0.35	0.094 ± 0.11
2012		0.25 ± 0.067	0.16 ± 0.11
2013		0.41 ± 0.00	
<b>BDE-100</b>			
2005		0.25 ± 0.15	
2006		0.23 ± 0.15	
2007			
2008			
2009		0.089 ± 0.034	0.014 ± 0.035
2010		0.13 ± 0.041	0.037 ± 0.042
2011		0.066 ± 0.068	0.024 ± 0.026
2012		0.075 ± 0.016	0.054 ± 0.048

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2013		0.11 ± 0.00	
<b>BDE-138</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
<b>BDE-153</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
<b>BDE-154</b>			
2005			
2006			
2007			
2008			
2009		0.070 ± 0.091	
2010		0.022 ± 0.025	0.0019 ± 0.0065
2011			0.0038 ± 0.0091
2012			
2013			
<b>BDE-183</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
<b>BDE-209</b>			
2005			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2006			$0.0020 \pm 0.0076$
2007		$0.27 \pm 0.42$	$0.021 \pm 0.073$
2008		$0.24 \pm 0.38$	
2009		$0.071 \pm 0.099$	
2010			
2011			
2012			
2013			$0.0020 \pm 0.0076$

170

171

172

173

174

175

176

177

178

179

180

181

182

183

184

185

186

187

188

189

190

191

192

193

194

195

196

197

198

199

200

201

202

203 **Part2.** Egbert from 2005 to 2008

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
<b>Non-PBDE HFRs</b>			
<i>anti-DDC-CO</i>			
2008			
<i>syn-DDC-CO</i>			
2008			
<b>PBDEs</b>			
<b>BDE-17</b>			
2005			
2006			
2007			
2008			
<b>BDE-28</b>			
2005			
2006			
2007			
2008			
<b>BDE-47</b>			
2005	0.46 ± 0.16	1.4 ± 0.66	0.17 ± 0.20
2006	0.28 ± 0.27	1.2 ± 0.52	0.18 ± 0.19
2007	0.15 ± 0.13	0.75 ± 0.14	0.11 ± 0.20
2008		0.79 ± 0.00	
<b>BDE-49</b>			
2005			
2006			
2007			
2008			
<b>BDE-66</b>			
2005			
2006			
2007			
2008			
<b>BDE-71</b>			
2005			
2006			
2007			
2007			
2008			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
<b>BDE-85</b>			
2005			
2006			
2007			
2008			
<b>BDE-99</b>			
2005	0.49 ± 0.18	0.74 ± 0.16	0.15 ± 0.19
2006	0.29 ± 0.22	1.1 ± 0.45	0.14 ± 0.22
2007	0.080 ± 0.096	0.54 ± 0.10	0.062 ± 0.14
2008		0.74 ± 0.00	
<b>BDE-100</b>			
2005	0.071 ± 0.073	0.18 ± 0.18	
2006		0.26 ± 0.16	
2007			
2008		0.23 ± 0.00	
<b>BDE-138</b>			
2005			
2006			
2007			
2008			
<b>BDE-153</b>			
2005			
2006			
2007			
2008			
<b>BDE-154</b>			
2005			
2006			
2007			
2008			
<b>BDE-183</b>			
2005			
2006			
2007			
2008			
<b>BDE-209</b>			
2005	0.070 ± 0.11		
2006	0.14 ± 0.25		
2007	0.053 ± 0.063		
2008			0.029 ± 0.10

	<b>Field Blank GFF (Average ± SD)</b>	<b>Field blank PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
<b>Non-PBDE HFRs</b>			
<b><i>anti</i>-DDC-CO</b>			
2008	0.051 ± 0.076	0.047 ± 0.049	
2009			0.0044 ± 0.016
2010			0.0016 ± 0.0037
2011			
2012	0.0056 ± 0.0087		
2013			0.0070 ± 0.022
2014			0.0063 ± 0.021
<b><i>syn</i>-DDC-CO</b>			
2008	0.034 ± 0.047		
2009			0.0066 ± 0.024
2010			0.0033 ± 0.0078
2011			
2012			
2013			
2014			
<b>TBP-AE</b>			
2009		0.0471 ± 0.026	0.0071 ± 0.0098
2010	0.018 ± 0.016	0.048 ± 0.059	0.0092 ± 0.021
2011		0.031 ± 0.035	0.00081 ± 0.0031
2012		0.048 ± 0.014	0.0087 ± 0.015
2013			
2014		0.046 ± 0.046	
<b>TBP-BAE</b>			
2009			
2010			
2011			
2012			
2013			
2014			
<b>BTBPE</b>			
2009			
2010			0.0094 ± 0.022
2011			0.0034 ± 0.013
2012			
2013			
2014			
<b>DBDPE</b>			
2009			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2010			
2011			
2012			
2013			
2014			
<b>DPTE</b>			
2009			
2010			
2011			0.0016 ± 0.0063
2012			
2013			
2014		0.12 ± 0.11	
<b>HBBz</b>			
2009		0.015 ± 0.029	0.023 ± 0.025
2010	0.023 ± 0.013	0.048 ± 0.036	0.0057 ± 0.013
2011			0.0014 ± 0.0055
2012		0.013 ± 0.020	0.0012 ± 0.0040
2013			
2014			
<b>HBCDD</b>			
2009			
2010			
2011			
2012			
2013			
2014			
<b>PBEB</b>			
2009			
2010			
2011			
2012			
2013			
2014			
<b>PBT</b>			
2009			0.019 ± 0.019
2010	0.023 ± 0.013		0.0043 ± 0.010
2011			
2012			
2013			
2014			
<b>EH-TBB</b>			
2009			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2010			
2011			
2012			0.011 ± 0.037
2013			
2014			
<b>PBDEs</b>			
<b>BDE-17</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
2014			
<b>BDE-28</b>			
2005			
2006			
2007			
2008			
2009	0.012 ± 0.016		
2010			
2011			
2012		0.017 ± 0.011	
2013			
2014			
<b>BDE-47</b>			
2005	0.38 ± 0.074	1.48 ± 0.57	0.16 ± 0.22
2006	0.28 ± 0.11	1.4 ± 0.59	0.17 ± 0.20
2007	0.20 ± 0.20	0.56 ± 0.22	0.12 ± 0.17
2008	0.47 ± 0.043	0.74 ± 0.20	0.25 ± 0.17
2009	0.27 ± 0.20	0.49 ± 0.15	0.11 ± 0.11
2010	0.070 ± 0.039	0.43 ± 0.31	0.13 ± 0.010
2011	0.088 ± 0.013	0.49 ± 0.20	0.11 ± 0.15
2012	0.047 ± 0.046	0.18 ± 0.20	0.064 ± 0.094
2013	0.061 ± 0.042	0.37 ± 0.030	0.054 ± 0.071
2014	0.31 ± 0.12	0.90 ± 0.39	0.73 ± 0.49
<b>BDE-49</b>			
2005			
2006			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2007			
2008			
2009			
2010			
2011			
2012			
2013			
2014			
<b>BDE-66</b>			
2005			
2006			
2007			0.0022 ± 0.0079
2008			
2009			
2010			
2011			
2012			
2013			
2014			
<b>BDE-71</b>			
2005			
2006			
2007			
2008			
2009			
2010			
2011			
2012			
2013			
2014			
<b>BDE-85</b>			
2005			
2006			
2007			0.0022 ± 0.0079
2008			0.016 ± 0.061
2009			0.0022 ± 0.0079
2010			
2011			0.00054 ± 0.0021
2012			
2013			
2014			
<b>BDE-99</b>			
2005	0.33 ± 0.084	1.1 ± 0.63	0.073 ± 0.14
2006	0.19 ± 0.10	0.97 ± 0.34	0.13 ± 0.19

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2007		0.27 ± 0.25	0.046 ± 0.087
2008	0.32 ± 0.039	0.58 ± 0.18	0.37 ± 0.76
2009	0.12 ± 0.062	0.52 ± 0.31	0.12 ± 0.13
2010	0.05 ± 0.032	0.39 ± 0.32	0.15 ± 0.13
2011	0.071 ± 0.020	0.46 ± 0.15	0.10 ± 0.18
2012	0.034 ± 0.034	0.19 ± 0.23	0.077 ± 0.084
2013	0.026 ± 0.051	0.36 ± 0.17	0.063 ± 0.093
2014	0.12 ± 0.062	0.163 ± 0.19	0.13 ± 0.15
<b>BDE-100</b>			
2005		0.21 ± 0.20	0.011 ± 0.032
2006		0.18 ± 0.18	0.0088 ± 0.021
2007			0.013 ± 0.022
2008	0.084 ± 0	0.15 ± 0.034	0.079 ± 0.12
2009	0.035 ± 0.025	0.13 ± 0.077	0.029 ± 0.031
2010	0.012 ± 0.016	0.15 ± 0.15	0.044 ± 0.046
2011		0.11 ± 0.037	0.014 ± 0.040
2012	0.012 ± 0.0030	0.12 ± 0.12	0.0030 ± 0.011
2013		0.13 ± 0.12	0.022 ± 0.050
2014	0.020 ± 0.029		
<b>BDE-138</b>			
2005			
2006			
2007			0.0044 ± 0.016
2008			0.0041 ± 0.015
2009			0.0044 ± 0.016
2010			
2011			
2012			
2013			
2014			
<b>BDE-153</b>			
2005			
2006			
2007			0.0044 ± 0.016
2008			0.029 ± 0.11
2009			0.0044 ± 0.016
2010			
2011			
2012			
2013			
2014			
<b>BDE-154</b>			
2005			
2006			

	<b>Field Blank</b> <b>GFF (Average ± SD)</b>	<b>Field blank</b> <b>PUF (Average ± SD)</b>	<b>Lab blank (Average ± SD)</b>
2007			0.0022 ± 0.0079
2008		0.024 ± 0.032	0.024 ± 0.092
2009		0.024 ± 0.032	0.0022 ± 0.0079
2010		0.053 ± 0.083	0.0019 ± 0.0064
2011			
2012		0.019 ± 0.025	
2013			
2014			
<b>BDE-183</b>			
2005			0.075 ± 0.27
2006			0.33 ± 1.2
2007			1.3 ± 3.4
2008			0.40 ± 1.2
2009			
2010			
2011			
2012			
2013			
2014			
<b>BDE-209</b>			
2005	0.012 ± 0.024		
2006	0.050 ± 0.062	0.098 ± 0.12	
2007	0.082 ± 0.12		0.022 ± 0.070
2008		1.6 ± 2.1	
2009			
2010			
2011			
2012			
2013			
2014			

206

207

208

209

210

211

212

213

214

215

216 **TableS2.** The % breakthrough for very volatile compounds

	BDE-17	BDE-28	BDE-47	BDE-49	TBP-AE	TBP-BAE	PBT	TBP-DBPE	PBEB	HBBz
Break Through (%)	0	3-12	7-30	7-15	5-38	0	0	0	20-25	7-21

217

218

219

220

221

222

223

224

225

226

227

228

229

230

231

232

233

234

235

236

237

238

239

240

241

242 **Table S3.** Concentrations of halogenated flame retardants at three sampling sites in the Canadian Great  
 243 Lakes Basin. When there is no data showing, it means the HFR compound was not detected.

244 **Part 1.** Burnt Island from 2005 to 2013

	Total (GFF+PUF) Mean (STD; Min-Max)	Gas Phase Mean (STD; Min-Max)	Particle Phase Mean (STD; Min-Max)
<b>Non-PBDE HFRs</b>			
<b><i>anti</i>-DDC-CO</b>			
2008	3.2 (4.6; 0.12 - 12)		3.2 (4.6; 0.12 - 12)
2009	0.24 (0.35; 0.030 - 1.3)	0.060 (0.0024; 0.055 - 0.062)	0.24 (0.35; 0.030 - 1.3)
2010	0.27 (0.41; 0.029 - 1.8)	0.083 (0.050; 0.046 - 0.14)	0.27 (0.42; 0.029 - 1.8)
2011	1.0 (2.2; 0.053 - 5.5)	0.11	1.0 (2.2; 0.053 - 5.5)
2012	0.34 (0.50; 0.026 - 1.8)		0.34 (0.50; 0.026 - 1.8)
2013	0.80		0.80
<b><i>syn</i>-DDC-CO</b>			
2008	2.4 (3.6; 0.23 - 7.8)		2.4 (3.6; 0.23 - 7.8)
2009	0.090 (0.10; 0.028 - 0.44)	0.11 (0.080; 0.055 - 0.24)	0.074 (0.083; 0.028 - 0.37)
2010	0.13 (0.23; 0.029 - 0.91)		0.13 (0.23; 0.029 - 0.91)
2011	0.30 (0.40; 0.066 - 1.1)	0.092	0.29 (0.45; 0.066 - 1.1)
2012	0.27 (0.36; 0.018 - 1.0)		0.27 (0.36; 0.018 - 0.98)
2013	0.22		0.22
<b>TBP-AE</b>			
2009	0.17 (0.12; 0.028 - 0.48)	0.16 (0.11; 0.059 - 0.48)	0.036 (0.012; 0.028 - 0.061)
2010	0.31 (0.15; 0.083 - 0.60)	0.30 (0.15; 0.083 - 0.57)	0.030 (0.00079; 0.029 - 0.031)
2011	0.23 (0.20; 0.047 - 0.86)	0.22 (0.20; 0.047 - 0.86)	0.048 (0.043; 0.018 - 0.079)
2012	0.17 (0.14; 0.061 - 0.63)	0.16 (0.14; 0.061 - 0.63)	
2013	0.085	0.085	0.11
<b>TBP-BAE</b>			
2009	0.087 (0.057; 0.060 - 0.19)	0.087 (0.057; 0.060 - 0.19)	
2010	0.083 (0.021; 0.059 - 0.10)	0.083 (0.021; 0.059 - 0.10)	
2011	0.039 (0.015; 0.019 - 0.062)	0.039 (0.015; 0.019 - 0.062)	
2012	0.025 (0.023; 0.0047 - 0.052)	0.045 (0.010; 0.038 - 0.052)	0.0057 (0.0015; 0.0047 - 0.0068)
<b>BTBPE</b>			
2009	0.081 (0.074; 0.029 - 0.28)		0.081 (0.074; 0.029 - 0.28)
2010	0.14 (0.14; 0.030 - 0.47)	0.12	0.15 (0.15; 0.030 - 0.47)
2011	0.42	0.42	
2012	0.044	0.044	
2013			
<b>DBDPE</b>			
2009			
2010			
2011	1.2		1.2
2012	0.59 (0.22; 0.27 - 0.88)		0.59 (0.22; 0.27 - 0.88)

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2013			
<b>DPTE</b>			
2009	0.050 (0.017; 0.031 - 0.060)	0.060 (0.00037; 0.060 - 0.060)	
2010	0.10 (0.071; 0.029 - 0.21)	0.12 (0.058; 0.037 - 0.18)	0.036 (0.013; 0.029 - 0.059)
2011	0.043 (0.026; 0.023 - 0.11)	0.032 (0.013; 0.020 - 0.055)	0.069 (0.054; 0.031 - 0.11)
2012	0.027 (0.013; 0.013 - 0.040)	0.034	0.024 (0.014; 0.013 - 0.040)
2013	0.11 (0.019; 0.091 - 0.13)	0.11 (0.019; 0.091 - 0.13)	
<b>HBBz</b>			
2009	0.18 (0.18; 0.029 - 0.95)	0.14 (0.18; 0.055 - 0.92)	0.067 (0.074; 0.029 - 0.37)
2010	0.30 (0.19; 0.059 - 0.84)	0.23 (0.15; 0.073 - 0.72)	0.087 (0.058; 0.029 - 0.33)
2011	0.14 (0.093; 0.048 - 0.37)	0.12 (0.091; 0.034 - 0.32)	0.046 (0.043; 0.011 - 0.13)
2012	0.17 (0.078; 0.060 - 0.31)	0.14 (0.079; 0.042 - 0.28)	0.031 (0.013; 0.014 - 0.059)
2013			
<b>HBCDD</b>			
2009	0.17 (0.27; 0.030 - 0.92)		0.17 (0.28; 0.030 - 0.92)
2010	0.50 (0.81; 0.091 - 2.0)		0.50 (0.81; 0.091 - 2.0)
2011			
2012	0.26 (0.30; 0.039 - 0.80)		0.26 (0.30; 0.039 - 0.80)
2013			
<b>PBEB</b>			
2009	0.060 (0.0015; 0.059 - 0.062)	0.061 (0.0016; 0.060 - 0.062)	
2010	0.051 (0.029; 0.019 - 0.12)	0.051 (0.029; 0.019 - 0.12)	
2011	0.021 (0.011; 0.0078 - 0.041)	0.021 (0.011; 0.0078 - 0.041)	
2012	0.018 (0.010; 0.0031 - 0.028)	0.023 (0.0046; 0.018 - 0.028)	0.0031 (0.000093; 0.0030 - 0.0032)
2013			
<b>PBT</b>			
2009		0.061 (0.0020; 0.057 - 0.063)	
2010		0.077 (0.025; 0.047 - 0.16)	
2011		0.059 (0.084; 0.0075 - 0.27)	
2012		0.041 (0.026; 0.014 - 0.12)	
2013			
<b>EH-TBB</b>			
2009	0.72 (0.42; 0.30 - 1.5)	0.52 (0.41; 0.060 - 1.5)	0.66 (0.46; 0.20 - 1.4)
2010	4.1 (6.0; 0.17 - 20)	6.2 (6.7; 0.54 - 20)	0.33 (0.10; 0.17 - 0.45)
2011	1.0 (1.0; 0.12 - 3.4)	0.94 (1.1; 0.12 - 3.2)	0.40 (0.22; 0.19 - 0.67)
2012	1.0 (2.0; 0.042 - 5.6)	3.4 (3.0; 1.2 - 5.5)	0.18 (0.24; 0.042 - 0.76)
2013			
<b>PBDEs</b>			
<b>BDE-17</b>			
2005	0.39 (0.17; 0.15 - 0.7)	0.39 (0.17; 0.15 - 0.74)	
2006	0.31 (0.14; 0.15 - 0.46)	0.31 (0.14; 0.15 - 0.46)	
2007	0.47 (0.32; 0.24 - 1.0)	0.50 (0.36; 0.24 - 1.0)	0.36

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2008	0.42 (0.27; 0.18 - 1.1)	0.42 (0.27; 0.18 - 1.1)	
2009	0.19 (0.19; 0.028 - 0.84)	0.19 (0.20; 0.057 - 0.84)	0.039 (0.021; 0.028 - 0.089)
2010	0.41 (1.1; 0.028 - 5.6)	0.45 (1.2; 0.032 - 5.6)	0.029 (0.00070; 0.028 - 0.030)
2011	0.11 (0.080; 0.016 - 0.24)	0.12 (0.084; 0.016 - 0.24)	0.073 (0.072; 0.027 - 0.16)
2012	0.20 (0.22; 0.0062 - 0.82)	0.17 (0.13; 0.043 - 0.47)	0.083 (0.20; 0.0037 - 0.57)
2013			
<b>BDE-28</b>			
2005	0.64 (0.45; 0.13 - 1.9)	0.64 (0.45; 0.13 - 1.9)	
2006	0.48 (0.39; 0.093 - 1.3)	0.48 (0.39; 0.093 - 1.3)	
2007	0.76 (0.74; 0.12 - 2.9)	0.71 (0.71; 0.12 - 2.7)	0.70 (0.73; 0.19 - 1.2)
2008	0.92 (0.71; 0.093 - 2.8)	1.0 (0.70; 0.30 - 2.8)	
2009	0.39 (0.52; 0.030 - 2.5)	0.38 (0.52; 0.057 - 2.5)	0.057 (0.054; 0.028 - 0.24)
2010	0.42 (0.68; 0.030 - 3.4)	0.42 (0.68; 0.027 - 3.3)	0.043 (0.028; 0.028 - 0.14)
2011	0.28 (0.17; 0.046 - 0.51)	0.23 (0.18; 0.020 - 0.51)	0.13 (0.17; 0.036 - 0.49)
2012	0.43 (0.35; 0.098 - 1.1)	0.37 (0.29; 0.048 - 0.98)	0.067 (0.14; 0.0047 - 0.51)
2013	0.030		0.030
<b>BDE-47</b>			
2005	7.7 (6.7; 1.6 - 26)	6.5 (5.8; 0.95 - 18)	1.3 (2.0; 0.34 - 12)
2006	6.7 (6.2; 1.3 - 31)	5.3 (5.1; 0.72 - 22)	1.3 (1.9; 0.24 - 8.8)
2007	17 (54; 0.60 - 290)	4.8 (7.1; 0.40 - 36)	12 (53; 0.17 - 290)
2008	17 (32; 0.14 - 170)	16 (34; 0.69 - 170)	3.0 (8.0; 0.11 - 36)
2009	11 (14; 0.82 - 54)	6.3 (10; 0.58 - 53)	4.7 (10; 0.18 - 37)
2010	10 (14; 0.90 - 48)	6.4 (10; 0.78 - 38)	3.8 (9.4; 0.088 - 40)
2011	20 (34; 1.8 - 140)	4.8 (4.7; 0.55 - 14)	15 (36; 0.27 - 140)
2012	7.5 (6.1; 1.9 - 24)	4.5 (3.0; 0.87 - 11)	3.2 (6.0; 0.35 - 23)
2013	6.9 (6.9; 0.74 - 14)	3.3 (5.6; 0.35 - 12)	4.8 (7.4; 0.24 - 13)
<b>BDE-49</b>			
2005	0.46 (0.25; 0.084 - 0.99)	0.47 (0.21; 0.16 - 0.99)	0.19 (0.15; 0.084 - 0.29)
2006	0.42 (0.31; 0.14 - 1.0)	0.42 (0.31; 0.14 - 1.0)	
2007	1.5 (1.9; 0.29 - 4.9)	0.60 (0.40; 0.29 - 1.3)	3.0 (2.7; 1.1 - 4.9)
2008	0.90 (0.97; 0.12 - 3.9)	0.91 (1.1; 0.12 - 3.9)	0.65 (0.08; 0.59 - 0.71)
2009	0.34 (0.38; 0.030 - 1.6)	0.26 (0.34; 0.057 - 1.6)	0.15 (0.24; 0.030 - 0.86)
2010	0.33 (0.39; 0.029 - 1.4)	0.25 (0.32; 0.030 - 1.3)	0.11 (0.21; 0.028 - 0.83)
2011	0.51 (0.79; 0.056 - 3.2)	0.18 (0.16; 0.029 - 0.47)	0.65 (1.1; 0.032 - 3.2)
2012	0.27 (0.24; 0.012 - 0.94)	0.19 (0.10; 0.063 - 0.39)	0.12 (0.19; 0.011 - 0.57)
2013	0.22 (0.16; 0.043 - 0.34)	0.29	0.19 (0.21; 0.043 - 0.34)
<b>BDE-66</b>			
2005	0.50 (0.33; 0.076 - 0.99)	0.47 (0.19; 0.26 - 0.71)	0.20 (0.11; 0.076 - 0.28)
2006	0.42 (0.11; 0.32 - 0.57)	0.42 (0.11; 0.32 - 0.57)	
2007	3.4 (2.6; 1.6 - 5.2)	0.56	3.1 (3.0; 1.0 - 5.2)
2008	1.0 (1.30; 0.24 - 3.6)	1.2 (1.6; 0.24 - 3.6)	0.61 (0.060; 0.56 - 0.65)
2009	0.33 (0.29; 0.030 - 0.90)	0.30 (0.24; 0.058 - 0.84)	0.22 (0.27; 0.030 - 0.77)
2010	0.26 (0.29; 0.028 - 0.95)	0.23 (0.23; 0.057 - 0.76)	0.15 (0.23; 0.028 - 0.83)
2011	0.39 (0.75; 0.026 - 3.0)	0.11 (0.085; 0.018 - 0.26)	0.67 (1.1; 0.026 - 3.0)

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2012	0.15 (0.21; 0.0090 - 0.75)	0.091 (0.045; 0.044 - 0.17)	0.12 (0.19; 0.0090 - 0.58)
2013	0.20 (0.092; 0.14 - 0.27)	0.14	0.27
<b>BDE-71</b>			
2005			
2006			
2007	0.44		0.44
2008			
2009	0.078 (0.053; 0.029 - 0.18)	0.12 (0.086; 0.058 - 0.18)	0.058 (0.022; 0.029 - 0.083)
2010	0.15 (0.16; 0.040 - 0.33)		0.064 (0.035; 0.040 - 0.089)
2011	0.11 (0.11; 0.049 - 0.31)	0.059 (0.014; 0.049 - 0.068)	0.15 (0.14; 0.054 - 0.31)
2012	0.54		0.54
2013			
<b>BDE-85</b>			
2005	0.64 (0.52; 0.27 - 1.0)	0.27	1.0
2006	0.45 (0.083; 0.36 - 0.52)		0.45 (0.083; 0.36 - 0.52)
2007	8.4 (12; 0.39 - 26)		8.4 (12; 0.39 - 26)
2008	4.8 (5.9; 0.23 - 13)	13	1.9 (1.5; 0.23 - 3.0)
2009	0.58 (1.05; 0.028 - 3.2)	0.31 (0.80; 0.058 - 3.0)	0.44 (0.95; 0.028 - 3.2)
2010	0.70 (1.3; 0.030 - 5.1)	0.26 (0.67; 0.057 - 2.9)	0.73 (1.4; 0.030 - 5.1)
2011	1.9 (4.0; 0.044 - 14)	0.20 (0.21; 0.044 - 0.53)	5.0 (5.9; 0.80 - 14)
2012	0.29 (0.58; 0.0090 - 1.9)	0.038 (0.0079; 0.032 - 0.043)	0.29 (0.57; 0.0090 - 1.9)
2013	1.0 (0.060; 1.0 - 1.1)	1.1	1.0
<b>BDE-99</b>			
2005	3.7 (4.2; 1.0 - 23)	2.3 (1.8; 0.65 - 7.0)	1.4 (3.6; 0.36 - 20)
2006	4.1 (3.8; 1.3 - 17)	2.4 (1.6; 0.55 - 6.1)	1.8 (3.3; 0.22 - 15)
2007	22 (92; 1.0 - 500)	0.98 (0.81; 0.35 - 4.2)	22 (93; 0.14 - 500)
2008	17 (53; 0.2 - 290)	14 (56; 0.40 - 290)	4.6 (15; 0.11 - 62)
2009	11 (20; 0.65 - 66)	3.1 (9.5; 0.30 - 53)	7.6 (18; 0.12 - 66)
2010	11 (24; 0.58 - 110)	3.7 (11; 0.44 - 60)	7.9 (22; 0.088 - 100)
2011	27 (66; 1.1 - 260)	1.3 (0.87; 0.57 - 3.4)	26 (67; 0.24 - 260)
2012	5.3 (10; 0.72 - 40)	0.91 (0.52; 0.28 - 2.0)	4.7 (11; 0.29 - 40)
2013	11 (12; 0.58 - 21)	5.6 (10; 0.42 - 21)	7.3 (12; 0.29 - 21)
<b>BDE-100</b>			
2005	0.95 (0.94; 0.080 - 4.9)	0.76 (0.50; 0.14 - 1.9)	0.30 (0.65; 0.079 - 3.7)
2006	0.93 (0.81; 0.23 - 3.7)	0.63 (0.40; 0.13 - 1.6)	0.49 (0.70; 0.12 - 2.8)
2007	6.1 (20; 0.084 - 91)	0.51 (0.41; 0.090 - 1.6)	9.6 (26; 0.084 - 91)
2008	4.5 (12; 0.12 - 55)	3.8 (12; 0.12 - 55)	1.6 (4.0; 0.12 - 12)
2009	2.2 (3.7; 0.14 - 12)	0.74 (1.8; 0.059 - 9.5)	1.5 (3.4; 0.028 - 12)
2010	2.2 (4.3; 0.13 - 18)	0.85 (2.1; 0.10 - 11)	1.4 (3.7; 0.029 - 18)
2011	5.4 (12; 0.25 - 48)	0.41 (0.35; 0.12 - 1.2)	5.0 (13; 0.050 - 48)
2012	1.0 (2.1; 0.24 - 8.0)	0.33 (0.21; 0.086 - 0.78)	1.0 (2.2; 0.066 - 8.0)
2013	2.2 (2.3; 0.15 - 4.2)	1.4 (2.3; 0.081 - 4.1)	1.4 (2.3; 0.061 - 4.1)

	Total (GFF+PUF)	Gas Phase	Particle Phase
	Mean (STD; Min-Max)	Mean (STD; Min-Max)	Mean (STD; Min-Max)
<b>BDE-138</b>			
2005			2.5 (2.9; 0.35 - 5.8)
2006			0.65 (0.083; 0.59 - 0.71)
2007	2.5 (2.9; 0.35 - 5.8)		0.30 (0.29; 0.030 - 0.71)
2008	1.3 (1.2; 0.59 - 2.7)	2.68	0.45 (0.42; 0.090 - 1.2)
2009	0.34 (0.31; 0.030 - 0.73)	0.73	1.1 (1.3; 0.29 - 2.5)
2010	0.55 (0.39; 0.090 - 1.2)	0.62	0.31 (0.14; 0.15 - 0.42)
2011	1.1 (1.3; 0.29 - 2.5)		0.22
2012	0.31 (0.14; 0.15 - 0.42)		
2013	0.27 (0.072; 0.22 - 0.32)	0.32	
<b>BDE-153</b>			
2005	0.88 (0.97; 0.20 - 2.0)		1.1 (1.3; 0.20 - 2.0)
2006	0.88 (0.30; 0.67 - 1.2)		0.88 (0.30; 0.67 - 1.2)
2007	16 (22; 0.87 - 49)		16 (22; 0.87 - 49)
2008	7.5 (8.9; 0.52 - 23)	13 (14; 2.8 - 23)	4.0 (3.0; 0.52 - 6.1)
2009	0.95 (2.0; 0.028 - 6.3)	0.55 (1.6; 0.055 - 6.0)	0.72 (1.7; 0.028 - 6.3)
2010	1.2 (2.5; 0.029 - 10)	0.38 (1.2; 0.037 - 5.3)	1.1 (2.6; 0.029 - 10)
2011	5.6 (9.4; 0.047 - 24)		5.6 (9.4; 0.047 - 24)
2012	0.48 (1.1; 0.011 - 3.7)	0.099	0.47 (1.1; 0.010 - 3.7)
2013	1.4 (1.1; 0.068 - 2.1)	2.1	1.0 (1.4; 0.068 - 2.0)
<b>BDE-154</b>			
2005	1.1 (0.75; 0.54 - 1.6)		1.1 (0.75; 0.54 - 1.6)
2006	0.69 (0.36; 0.24 - 1.2)		0.72 (0.41; 0.24 - 1.2)
2007	14 (19; 0.75 - 41)		14 (19; 0.75 - 41)
2008	7.7 (9.6; 0.43 - 25)	14 (15; 3.0 - 25)	3.6 (2.8; 0.43 - 5.6)
2009	0.89 (1.7; 0.029 - 5.4)	0.39 (1.2; 0.055 - 5.3)	0.69 (1.6; 0.028 - 5.2)
2010	1.0 (2.0; 0.029 - 8.4)	0.28 (1.0; 0.059 - 5.0)	0.87 (2.0; 0.028 - 8.3)
2011	2.3 (5.8; 0.038 - 22)	0.10 (0.13; 0.033 - 0.42)	4.6 (8.1; 0.021 - 22)
2012	0.41 (0.92; 0.015 - 3.4)	0.048 (0.016; 0.031 - 0.067)	0.43 (0.95; 0.015 - 3.4)
2013	1.2 (1.0; 0.055 - 1.8)	1.8	0.88 (1.2; 0.055 - 1.7)
<b>BDE-183</b>			
2005	0.62		0.62
2006			
2007	0.74		0.74
2008			
2009	0.10 (0.065; 0.030 - 0.24)	0.24	0.086 (0.052; 0.030 - 0.20)
2010	0.13 (0.11; 0.030 - 0.39)	0.20	0.11 (0.11; 0.030 - 0.39)
2011	0.35 (0.37; 0.088 - 0.61)		0.35 (0.37; 0.088 - 0.61)
2012	0.10 (0.16; 0.014 - 0.43)		0.10 (0.16; 0.014 - 0.43)
2013	0.12		0.12
<b>BDE-209</b>			
2005	1.1 (1.3; 0.11 - 6.5)	1.0 (1.4; 0.15 - 3.2)	0.96 (1.2; 0.11 - 6.5)
2006	1.5 (2.2; 0.084 - 12)	0.85 (0.95; 0.20 - 4.2)	1.0 (2.2; 0.065 - 12)
2007	0.75 (0.68; 0.092 - 3.4)	0.47 (0.71; 0.084 - 3.0)	0.48 (0.40; 0.049 - 1.8)

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2008	1.7 (4.6; 0.10 - 25)	0.55 (0.42; 0.15 - 1.2)	1.6 (4.7; 0.087 - 25)
2009	0.81 (0.78; 0.024 - 3.0)	0.26 (0.084; 0.16 - 0.46)	0.72 (0.75; 0.024 - 3.0)
2010	0.50 (0.58; 0.024 - 1.7)		0.50 (0.58; 0.024 - 1.7)
2011	1.2 (0.84; 0.28 - 3.0)		1.2 (0.84; 0.28 - 3.0)
2012	0.34 (0.24; 0.069 - 0.80)		0.34 (0.24; 0.069 - 0.80)
2013	0.12		0.12

245

246

247

248

249

250

251

252

253

254

255

256

257

258

259

260

261

262

263

264

265

266

267

268

269

270

271

272

273

274

275

276

277

278

279

**Part 2.** Egbert from 2005 to 2008

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
<b>Non-PBDE HFRs</b>			
<i>anti-DDC-CO</i>			
2008	12 (18; 0.40 - 39)		12 (18; 0.40 - 39)
<i>syn-DDC-CO</i>			
2008	6.2 (7.1; 0.47 - 14)		6.2 (7.1; 0.47 - 14)
<b>PBDEs</b>			
<b>BDE-17</b>	0.36 (0.13; 0.55 - 0.16) 0.38 (0.29; 0.737 - 0.08) 0.33 (0.21; 0.61 - 0.13) 0.23	0.36 (0.13; 0.16 - 0.55) 0.34 (0.32; 0.078 - 0.74) 0.22 (0.13; 0.13 - 0.31) 0.23	0.50 0.45 (0.24; 0.61 - 0.28)
<b>BDE-28</b>	0.88 (1.0; 0.10 - 4.6) 0.74 (0.74; 0.17 - 2.8) 0.46 (0.48; 0.12 - 2.0) 0.27 (0.044; 0.24 - 0.30)	0.92 (1.0; 0.18 - 4.6) 0.66 (0.67; 0.17 - 2.8) 0.44 (0.48; 0.12 - 2.0) 0.27 (0.044; 0.24 - 0.30)	0.096 1.6 0.19
<b>BDE-47</b>	9.6 (7.5; 1.2 - 27) 23 (81; 0.93 - 450) 3.3 (2.2; 0.73 - 7.8) 3.3 (1.3; 1.7 - 5.8)	8.5 (7.6; 0.64 - 26) 7.2 (7.7; 0.56 - 37) 2.9 (2.1; 0.66 - 7.5) 1.7 (1.0; 0.85 - 3.5)	1.1 (0.7; 0.43 - 3.0) 16 (80; 0.23 - 440) 0.37 (0.23; 0.072 - 0.94) 1.6 (0.64; 0.60 - 2.3)
<b>BDE-49</b>	0.48 (0.24; 0.13 - 0.93) 0.91 (1.9; 0.12 - 7.7) 0.33 (0.033; 0.31 - 0.37) 0.77	0.50 (0.22; 0.13 - 0.84) 0.44 (0.30; 0.20 - 1.2) 0.33 (0.033; 0.31 - 0.37) 0.77	0.11 (0.033; 0.085 - 0.13) 3.7 (5.1; 0.12 - 7.3)
<b>BDE-66</b>	0.27 (0.15; 0.092 - 0.55) 2.0 (3.4; 0.21 - 8.0)	0.33 (0.13; 0.21 - 0.55) 0.50 (0.24; 0.21 - 0.78)	0.13 (0.050; 0.092 - 0.16) 8.0
<b>BDE-71</b>	0.29		

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
<b>BDE-85</b>			
2005			
2006	28		
2007			
2008			
<b>BDE-99</b>			
2005	3.7 (2.1; 0.89 - 10)	2.6 (2.0; 0.57 - 8.6)	1.1 (0.65; 0.33 - 3.6)
2006	22 (100; 0.61 - 560)	2.9 (2.9; 0.43 - 15)	20 (100; 0.21 - 550)
2007	1.6 (0.82; 0.43 - 3.1)	1.1 (0.66; 0.25 - 2.8)	0.46 (0.39; 0.086 - 1.5)
2008	2.6 (0.94; 1.7 - 4.4)	0.94 (0.36; 0.44 - 1.4)	1.6 (0.91; 0.71 - 3.0)
<b>BDE-100</b>			
2005	1.1 (0.70; 0.18 - 2.6)	0.92 (0.68; 0.20 - 2.3)	0.29 (0.16; 0.11 - 0.72)
2006	5.0 (22; 0.13 - 120)	0.89 (0.75; 0.20 - 3.7)	5.6 (25; 0.12 - 120)
2007	0.47 (0.19; 0.087 - 0.71)	0.41 (0.18; 0.12 - 0.69)	0.15 (0.084; 0.052 - 0.27)
2008	0.61 (0.27; 0.20 - 1.0)	0.26 (0.084; 0.16 - 0.36)	0.50 (0.13; 0.30 - 0.66)
<b>BDE-138</b>			
2005	5.1		
2006			
2007			
2008			
<b>BDE-153</b>			
2005	0.60 (0.62; 0.16 - 1.0)		0.60 (0.62; 0.16 - 1.0)
2006	46		46
2007	0.090		0.090
2008			
<b>BDE-154</b>			
2005	0.27 (0.21; 0.14 - 0.51)		0.27 (0.21; 0.14 - 0.51)
2006	8.5 (18; 0.15 - 41)		8.5 (18; 0.15 - 41)
2007			
2008	0.57		0.57
<b>BDE-183</b>			
2005			
2006	0.65		
2007	0.27		
2008			
<b>BDE-209</b>			
2005	9.2 (20; 0.38 - 100)	1.1 (1.7; 0.14 - 5.1)	8.9 (20; 0.23 - 100)
2006	9.7 (14; 0.31 - 52)	4.5 (11; 0.18 - 42)	7.6 (12; 0.31 - 52)
2007	5.6 (6.8; 0.32 - 28)	0.40 (0.038; 0.37 - 0.43)	5.6 (6.8; 0.32 - 28)
2008	34 (46; 4.7 - 130)		34 (46; 4.7 - 130)

**Part 3.** Point Petre from 2005 to 2014.

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
<b>Non-PBDE HFRs</b>			
<b>anti-DDC-CO</b>			
2008	16 (47; 0.085 - 250)	0.093 (0.081; 0.058 - 0.30)	16 (47; 0.085 - 250)
2009	3.0 (7.8; 0.028 - 40)	0.25 (0.40; 0.055 - 1.1)	3.0 (7.8; 0.028 - 40)
2010	2.0 (3.5; 0.058 - 16)	0.06 (0.022; 0.029 - 0.088)	2.0 (3.5; 0.058 - 16)
2011	7.1 (16; 0.14 - 51)		7.1 (16; 0.14 - 51)
2012	6.6 (16; 0.022 - 58)	0.073 (0.055; 0.027 - 0.13)	6.6 (16; 0.022 - 58)
2013	3.1 (5.5; 0.34 - 15)		3.1 (5.5; 0.34 - 15)
2014	1.1 (1.2; 0.28 - 3.3)		1.1 (1.2; 0.28 - 3.3)
<b>syn-DDC-CO</b>			
2008	6.6 (17; 0.082 - 91)	0.10 (0.065; 0.058 - 0.24)	6.6 (17; 0.082 - 91)
2009	1.2 (2.8; 0.030 - 12)	0.081 (0.053; 0.055 - 0.18)	1.1 (2.8; 0.030 - 12)
2010	0.81 (1.3; 0.058 - 5.1)	0.051	0.81 (1.3; 0.057 - 5.1)
2011	4.2 (11; 0.29 - 33)		4.2 (11; 0.29 - 33)
2012	1.6 (3.3; 0.010 - 13)	0.053 (0.036; 0.020 - 0.091)	1.5 (3.3; 0.010 - 13)
2013	0.71 (0.80; 0.21 - 2.1)		0.71 (0.80; 0.21 - 2.1)
2014	0.31 (0.31; 0.14 - 0.74)		0.31 (0.31; 0.14 - 0.77)
<b>TBP-AE</b>			
2009	0.16 (0.11; 0.058 - 0.48)	0.16 (0.11; 0.058 - 0.48)	
2010	1.0 (1.6; 0.089 - 7.0)	1.0 (1.6; 0.089 - 7.0)	0.060 (0.069; 0.029 - 0.27)
2011	1.0 (1.6; 0.042 - 6.2)	1.0 (1.6; 0.042 - 6.2)	0.19
2012	0.41 (0.20; 0.12 - 0.74)	0.40 (0.20; 0.12 - 0.74)	0.025 (0.014; 0.013 - 0.041)
2013	0.15 (0.078; 0.068 - 0.34)	0.15 (0.078; 0.068 - 0.34)	
2014	0.44 (0.44; 0.15 - 1.3)	0.44 (0.44; 0.15 - 1.3)	
<b>TBP-BAE</b>			
2009	0.089 (0.059; 0.059 - 0.18)	0.089 (0.059; 0.059 - 0.18)	0.25
2010	0.094 (0.043; 0.046 - 0.16)	0.090 (0.043; 0.046 - 0.16)	0.057
2011	0.062 (0.031; 0.027 - 0.11)	0.062 (0.031; 0.027 - 0.11)	
2012	0.048 (0.027; 0.024 - 0.12)	0.048 (0.027; 0.024 - 0.12)	0.028
2013	0.31 (0.36; 0.059 - 0.56)	0.31 (0.36; 0.059 - 0.56)	
2014	0.097 (0.021; 0.083 - 0.11)	0.097 (0.021; 0.083 - 0.11)	
<b>BTBPE</b>			
2009			
2010	0.14 (0.12; 0.029 - 0.36)	0.12 (0.019; 0.10 - 0.14)	0.11 (0.12; 0.029 - 0.36)
2011			
2012			
2013			
2014			
<b>DBDPE</b>			
2009			
2010			
2011			

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2012	0.31 (0.22; 0.088 - 0.98)		0.31 (0.22; 0.088 - 0.98)
2013	0.73 (0.62; 0.24 - 1.7)		0.73 (0.62; 0.24 - 1.7)
2014			
<b>DPTE</b>			
2009	0.061 (0.00023; 0.060 - 0.061)	0.060 (0.00023; 0.060 - 0.061)	0.046 (0.021; 0.029 - 0.086)
2010	0.18 (0.17; 0.029 - 0.56)	0.22 (0.18; 0.057 - 0.56)	
2011	0.054 (0.025; 0.029 - 0.088)	0.054 (0.025; 0.029 - 0.09)	
2012	0.052 (0.054; 0.018 - 0.17)	0.043 (0.038; 0.018 - 0.13)	0.030 (0.024; 0.013 - 0.047)
2013	0.23 (0.26; 0.050 - 0.76)	0.23 (0.26; 0.050 - 0.76)	
2014	0.50 (0.37; 0.19 – 1.4)	0.50 (0.37; 0.19 – 1.4)	
<b>HBBz</b>			
2009	0.13 (0.17; 0.057 - 0.88)	0.13 (0.17; 0.057 - 0.88)	
2010	0.33 (0.37; 0.029 - 1.9)	0.30 (0.37; 0.045 - 1.8)	0.054 (0.020; 0.029 - 0.12)
2011	0.20 (0.16; 0.049 - 0.55)	0.19 (0.16; 0.049 - 0.55)	0.049 (0.031; 0.023 - 0.083)
2012	0.21 (0.16; 0.028 - 0.57)	0.20 (0.16; 0.028 - 0.57)	0.017 (0.014; 0.0064 - 0.051)
2013	0.25 (0.16; 0.11 - 0.49)	0.25 (0.16; 0.11 - 0.49)	
2014	0.19 (0.11; 0.051 – 0.39)		
<b>HBCDD</b>			
2009	0.16 (0.094; 0.059 - 0.35)		0.16 (0.094; 0.059 - 0.35)
2010	0.31 (0.17; 0.090 - 0.54)		0.31 (0.17; 0.090 - 0.54)
2011	0.38		0.38
2012	0.054 (0.044; 0.023 - 0.085)		0.054 (0.044; 0.023 - 0.085)
2013			
2014			
<b>PBEB</b>			
2009	0.060 (0.032; 0.024 - 0.14)	0.060 (0.032; 0.024 - 0.14)	
2010	0.045 (0.030; 0.014 - 0.12)	0.045 (0.030; 0.014 - 0.12)	
2011	0.034 (0.023; 0.012 - 0.087)	0.034 (0.023; 0.012 - 0.087)	
2012	0.11 (0.067; 0.063 - 0.16)	0.11 (0.067; 0.063 - 0.16)	
2013			
2014	0.022	0.022	
<b>PBT</b>			
2009		0.059 (0.0010; 0.058 - 0.061)	
2010		0.071 (0.047; 0.013 - 0.18)	
2011		0.050 (0.032; 0.0080 - 0.12)	
2012		0.050 (0.027; 0.014 - 0.10)	
2013		0.22 (0.16; 0.036 - 0.52)	
2014		0.083 (0.046; 0.034 – 0.17)	
<b>EH-TBB</b>			
2009	0.60 (0.10; 0.53 - 0.67)		0.60 (0.10; 0.53 - 0.67)
2010	6.0 (5.4; 0.15 - 14)	7.0 (5.2; 0.80 - 14)	0.13
2011	2.5 (2.3; 0.98 - 5.9)	3.0 (2.6; 0.98 - 5.9)	1.3

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2012	0.46 (0.36; 0.051 - 1.2)	0.38 (0.23; 0.075 - 0.78)	0.24 (0.39; 0.051 - 1.2)
2013			
2014	2.4 (2.1; 0.32 – 4.5)	3.4 (1.5; 2.4 – 4.5)	0.32
<b>PBDEs</b>			
<b>BDE-17</b>			
2005	0.42 (0.17; 0.14 - 0.70)	0.42 (0.17; 0.14 - 0.70)	
2006	0.36 (0.19; 0.16 - 0.71)	0.36 (0.19; 0.16 - 0.71)	
2007			
2008	0.18 (0.14; 0.057 - 0.57)	0.17 (0.14; 0.057 - 0.57)	0.088 (0.0002; 0.088 - 0.088)
2009	0.11 (0.062; 0.030 - 0.24)	0.11 (0.058; 0.056 - 0.24)	0.030 (0.00019; 0.029 - 0.030)
2010	0.14 (0.10; 0.056 - 0.49)	0.14 (0.10; 0.056 - 0.49)	0.029 (0.00068; 0.029 - 0.030)
2011	0.12 (0.062; 0.043 - 0.21)	0.12 (0.062; 0.043 - 0.21)	
2012	0.10 (0.074; 0.018 - 0.26)	0.10 (0.072; 0.018 - 0.25)	0.010 (0.0048; 0.0068 - 0.014)
2013	0.19 (0.080; 0.10 - 0.28)	0.19 (0.080; 0.10 - 0.28)	
2014	0.14 (0.089; 0.015 – 0.26)	0.17 (0.068; 0.10 – 0.26)	0.015
<b>BDE-28</b>			
2005	0.74 (0.39; 0.24 - 1.6)	0.74 (0.39; 0.24 - 1.6)	
2006	0.63 (0.30; 0.29 - 1.4)	0.63 (0.30; 0.29 - 1.4)	
2007	0.36 (0.11; 0.21 - 0.54)	0.38 (0.11; 0.24 - 0.54)	0.21
2008	0.31 (0.27; 0.058 - 1.0)	0.29 (0.27; 0.057 - 1.0)	0.086 (0.0040; 0.080 - 0.091)
2009	0.22 (0.16; 0.055 - 0.6)	0.21 (0.16; 0.055 - 0.6)	0.030 (0.00071; 0.028 - 0.030)
2010	0.25 (0.26; 0.046 - 1.2)	0.24 (0.26; 0.046 - 1.2)	0.034 (0.011; 0.029 - 0.057)
2011	0.24 (0.21; 0.022 - 0.63)	0.24 (0.21; 0.020 - 0.63)	
2012	0.32 (0.27; 0.045 - 0.89)	0.31 (0.27; 0.041 - 0.88)	0.0062 (0.0048; 0.0019 - 0.021)
2013	0.34 (0.29; 0.065 - 1.0)	0.34 (0.29; 0.065 - 0.98)	
2014	0.40 (0.29; 0.024 – 0.87)	0.47 (0.25; 0.23 – 0.87)	0.024
<b>BDE-47</b>			
2005	9.8 (7.1; 2.6 - 28)	8.7 (7.2; 1.6 - 27)	1.1 (0.88; 0.31 - 3.9)
2006	6.6 (5.4; 0.49 - 24)	6.2 (5.4; 0.75 - 23)	0.63 (0.44; 0.22 - 2.6)
2007	5.0 (7.7; 1.5 - 43)	3.2 (3.3; 0.95 - 17)	1.9 (7.1; 0.27 - 39)
2008	5.8 (4.0; 1.9 - 17)	4.1 (3.3; 1.3 - 12)	1.8 (3.0; 0.41 - 15)
2009	3.5 (2.3; 0.98 - 10)	2.9 (2.3; 0.80 - 9.2)	0.55 (0.51; 0.062 - 2.4)
2010	2.7 (1.9; 0.20 - 9.2)	2.4 (1.9; 0.50 - 9.0)	0.33 (0.43; 0.090 - 2.5)
2011	2.7 (1.1; 0.99 - 4.7)	2.4 (1.1; 0.80 - 4.5)	0.23 (0.11; 0.11 - 0.52)
2012	2.9 (1.4; 0.99 - 5.6)	2.7 (1.3; 0.84 - 5.5)	0.23 (0.30; 0.071 - 1.2)
2013	2.5 (1.3; 1.0 - 5.1)	2.3 (1.3; 0.86 - 4.9)	0.27 (0.22; 0.091 - 0.81)
2014	4.6 (1.9; 1.8 – 8.7)	4.2 (4.8; 1.5 – 8.0)	0.43 (0.16; 0.29 – 0.77)
<b>BDE-49</b>			
2005	0.49 (0.29; 0.11 - 1.2)	0.57 (0.26; 0.29 - 1.2)	0.11 (0.037; 0.062 - 0.15)
2006	0.40 (0.18; 0.14 - 0.72)	0.40 (0.18; 0.14 - 0.72)	
2007	0.39 (0.34; 0.12 - 1.1)	0.25 (0.10; 0.12 - 0.36)	1.1
2008	0.22 (0.13; 0.058 - 0.54)	0.17 (0.14; 0.057 - 0.54)	0.11 (0.071; 0.080 - 0.34)
2009	0.14 (0.090; 0.058 - 0.40)	0.12 (0.087; 0.055 - 0.36)	0.035 (0.012; 0.028 - 0.060)
2010	0.13 (0.12; 0.029 - 0.58)	0.13 (0.12; 0.051 - 0.58)	0.044 (0.045; 0.029 - 0.17)
2011	0.15 (0.075; 0.066 - 0.26)	0.15 (0.075; 0.066 - 0.26)	

	Total (GFF+PUF)	Gas Phase	Particle Phase
	Mean (STD; Min-Max)	Mean (STD; Min-Max)	Mean (STD; Min-Max)
2012	0.14 (0.091; 0.028 - 0.30)	0.13 (0.085; 0.022 - 0.28)	0.013 (0.021; 0.0032 - 0.081)
2013	0.16 (0.11; 0.10 - 0.35)	0.16 (0.11; 0.10 - 0.35)	
2014	0.18 (0.098; 0.027 – 0.28)	0.21 (0.071; 0.12 – 0.28)	0.027
<b>BDE-66</b>			
2005	0.13		0.13
2006			
2007	1.1		1.1
2008	0.18 (0.13; 0.057 - 0.59)	0.15 (0.13; 0.057 - 0.59)	0.12 (0.088; 0.080 - 0.34)
2009	0.10 (0.069; 0.055 - 0.35)	0.080 (0.042; 0.055 - 0.18)	0.073 (0.089; 0.029 - 0.29)
2010	0.14 (0.16; 0.029 - 0.59)	0.15 (0.18; 0.046 - 0.59)	0.058 (0.064; 0.029 - 0.17)
2011	0.10 (0.030; 0.072 - 0.13)	0.10 (0.030; 0.072 - 0.13)	
2012	0.075 (0.063; 0.0056 - 0.22)	0.084 (0.048; 0.023 - 0.15)	0.019 (0.024; 0.0048 - 0.071)
2013			
2014			
<b>BDE-71</b>			
2005	0.29		0.29
2006			
2007			
2008	0.22 (0.18; 0.088 - 0.43)	0.059	0.20 (0.20; 0.088 - 0.43)
2009	0.058	0.058	
2010			
2011			
2012	0.067	0.067	
2013			
2014			
<b>BDE-85</b>			
2005	0.12		0.12
2006			
2007	1.9 (2.2; 0.35 - 3.4)	0.35	
2008	0.28 (0.50; 0.057 - 1.7)	0.16 (0.32; 0.057 - 1.5)	0.35 (0.59; 0.084 - 1.6)
2009	0.069 (0.040; 0.029 - 0.20)	0.072 (0.034; 0.055 - 0.18)	0.042 (0.016; 0.029 - 0.060)
2010	0.18 (0.37; 0.029 - 1.8)	0.21 (0.43; 0.055 - 1.8)	0.080 (0.064; 0.029 - 0.23)
2011	0.067	0.067	
2012	0.069 (0.054; 0.016 - 0.18)	0.053 (0.032; 0.020 - 0.10)	0.049 (0.066; 0.0078 - 0.18)
2013			
2014	0.74 (0.21; 0.55 – 0.97)	0.74 (0.21; 0.55 – 0.97)	
<b>BDE-99</b>			
2005	4.2 (2.0; 1.6 - 8.3)	3.2 (2.1; 0.76 - 7.5)	1.1 (0.85; 0.30 - 3.4)
2006	3.0 (1.8; 0.69 - 8.6)	2.2 (1.5; 0.31 - 7.2)	0.78 (1.0; 0.092 - 5.2)
2007	4.3 (12; 0.77 - 69)	1.5 (2.4; 0.34 - 11)	3.0 (13; 0.24 - 68)
2008	5.0 (8.0; 1.2 - 37)	2.1 (2.9; 0.70 - 17)	3.1 (7.7; 0.33 - 36)
2009	1.5 (0.48; 0.82 - 2.7)	1.1 (0.46; 0.52 - 2.6)	0.40 (0.31; 0.040 - 1.3)
2010	2.0 (1.2; 0.38 - 7.1)	1.6 (0.75; 0.55 - 3.9)	0.46 (0.94; 0.090 - 5.2)
2011	1.8 (0.40; 1.3 - 2.5)	1.6 (0.40; 1.12 - 2.3)	0.25 (0.17; 0.090 - 0.78)

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2012	2.1 (1.7; 0.66 - 6.1)	1.5 (0.81; 0.57 - 3.2)	0.61 (1.2; 0.059 - 4.6)
2013	1.3 (0.43; 0.32 - 1.9)	1.1 (0.46; 0.23 - 1.8)	0.27 (0.27; 0.062 - 0.79)
2014	3.4 (3.8; 0.58 - 12)	3.2 (3.7; 0.46 - 12)	0.17 (0.075; 0.090 - 0.34)
<b>BDE-100</b>			
2005	1.0 (0.54; 0.34 - 2.3)	0.91 (0.59; 0.24 - 2.1)	0.30 (0.20; 0.077 - 0.80)
2006	0.78 (0.56; 0.070 - 2.6)	0.79 (0.54; 0.19 - 2.6)	0.21 (0.16; 0.070 - 0.73)
2007	1.1 (2.8; 0.085 - 14)	0.66 (0.66; 0.17 - 2.5)	1.5 (4.1; 0.085 - 13)
2008	1.2 (1.6; 0.35 - 7.2)	0.6 (0.88; 0.23 - 5.1)	0.63 (1.4; 0.080 - 6.9)
2009	0.44 (0.19; 0.17 - 0.97)	0.33 (0.17; 0.12 - 0.85)	0.11 (0.085; 0.029 - 0.35)
2010	0.46 (0.24; 0.087 - 1.4)	0.37 (0.16; 0.13 - 0.81)	0.10 (0.16; 0.029 - 0.92)
2011	0.41 (0.086; 0.26 - 0.56)	0.37 (0.081; 0.21 - 0.49)	0.064 (0.034; 0.031 - 0.14)
2012	0.46 (0.27; 0.20 - 1.0)	0.36 (0.15; 0.17 - 0.69)	0.10 (0.18; 0.015 - 0.65)
2013	0.26 (0.12; 0.14 - 0.49)	0.27 (0.13; 0.15 - 0.49)	0.11 (0.065; 0.047 - 0.19)
2014	0.76 (0.75; 0.13 - 2.4)	0.73 (0.72; 0.13 - 2.3)	0.066 (0.017; 0.040 - 0.081)
<b>BDE-138</b>			
2005			
2006			
2007			
2008	0.26 (0.19; 0.059 - 0.43)	0.18 (0.20; 0.059 - 0.41)	0.39 (0.062; 0.34 - 0.43)
2009	0.075 (0.057; 0.029 - 0.18)	0.10 (0.069; 0.055 - 0.18)	0.044 (0.022; 0.029 - 0.060)
2010			0.057
2011			
2012	0.035 (0.013; 0.020 - 0.047)		0.035 (0.013; 0.020 - 0.047)
2013			
2014	0.42	0.42	
<b>BDE-153</b>			
2005	0.44 (0.23; 0.30 - 0.71)		0.44 (0.23; 0.30 - 0.71)
2006			
2007	3.9 (4.4; 0.75 - 7.0)		7.0
2008	0.39 (0.70; 0.057 - 3.1)	0.20 (0.46; 0.057 - 2.2)	0.38 (0.72; 0.084 - 3.0)
2009	0.088 (0.046; 0.029 - 0.23)	0.065 (0.028; 0.055 - 0.18)	0.056 (0.034; 0.028 - 0.15)
2010	0.13 (0.14; 0.029 - 0.74)	0.080 (0.031; 0.043 - 0.15)	0.094 (0.14; 0.029 - 0.63)
2011	0.086	0.086	
2012	0.11 (0.13; 0.010 - 0.44)	0.067 (0.034; 0.030 - 0.13)	0.085 (0.14; 0.010 - 0.44)
2013	0.084 (0.0099; 0.077 - 0.091)		0.084 (0.010; 0.077 - 0.091)
2014	1.6 (0.95; 0.39 - 2.6)	1.6 (0.95; 0.39 - 2.6)	
<b>BDE-154</b>			
2005	0.38 (0.10; 0.28 - 0.48)		0.38 (0.10; 0.28 - 0.48)
2006	0.39 (0.18; 0.22 - 0.58)		0.39 (0.18; 0.22 - 0.58)
2007	3.5 (3.9; 0.75 - 6.3)		6.4
2008	0.43 (0.79; 0.057 - 2.9)	0.18 (0.46; 0.057 - 2.5)	0.40 (0.81; 0.084 - 2.8)
2009	0.095 (0.044; 0.029 - 0.23)	0.065 (0.024; 0.055 - 0.18)	0.048 (0.026; 0.028 - 0.12)
2010	0.12 (0.080; 0.030 - 0.46)	0.091 (0.035; 0.033 - 0.18)	0.068 (0.081; 0.029 - 0.34)
2011	0.076 (0.042; 0.045 - 0.15)	0.080 (0.048; 0.045 - 0.15)	0.063

	<b>Total (GFF+PUF)</b> <b>Mean (STD; Min-Max)</b>	<b>Gas Phase</b> <b>Mean (STD; Min-Max)</b>	<b>Particle Phase</b> <b>Mean (STD; Min-Max)</b>
2012	0.12 (0.14; 0.0054 - 0.48)	0.078 (0.048; 0.030 - 0.18)	0.059 (0.12; 0.0035 - 0.43)
2013	0.064		0.064
2014	1.0 (0.79; 0.24 – 2.0)	1.0 (0.79; 0.24 – 2.0)	
<b>BDE-183</b>			
2005	1.9		1.9
2006			
2007			
2008	0.41 (0.55; 0.059 - 2.0)	0.78 (0.76; 0.059 - 2.0)	0.17 (0.15; 0.084 - 0.52)
2009	0.21 (0.37; 0.029 - 1.2)	0.82 (0.56; 0.18 - 1.22)	0.063 (0.034; 0.029 - 0.12)
2010	0.089 (0.043; 0.029 - 0.15)		0.089 (0.043; 0.029 - 0.15)
2011	0.41		0.41
2012	0.063 (0.028; 0.027 - 0.095)		0.063 (0.028; 0.027 - 0.095)
2013			
2014			
<b>BDE-209</b>			
2005	6.1 (17; 0.30 - 72)	1.6 (1.5; 0.43 - 3.4)	5.8 (17; 0.30 - 72)
2006	1.3 (0.97; 0.14 - 3.4)	0.52 (0.39; 0.10 - 1.4)	1.0 (0.77; 0.14 - 3.0)
2007	1.7 (2.2; 0.18 - 12)	0.27 (0.22; 0.078 - 0.95)	1.6 (2.2; 0.18 - 12)
2008	5.2 (3.4; 0.68 - 14)	0.35 (0.16; 0.24 - 0.46)	5.2 (3.4; 0.68 - 14)
2009	1.6 (1.6; 0.072 - 7.5)	0.18 (0.044; 0.11 - 0.24)	1.6 (1.6; 0.072 - 7.5)
2010	0.68 (0.74; 0.017 - 3.2)		0.68 (0.74; 0.017 - 3.2)
2011	1.7 (1.1; 0.46 - 4.6)		1.7 (1.1; 0.46 - 4.6)
2012	0.90 (1.5; 0.055 - 4.5)		0.90 (1.5; 0.055 - 4.5)
2013	1.4 (0.78; 0.57 - 2.6)		1.4 (0.78; 0.57 - 2.6)
2014	1.8 (0.32; 1.5 – 2.2)		1.8 (0.32; 1.5 – 2.2)

284

285

286

287

288

289

290

291

292

293

294

295 **Table S4.** Pearson correlation coefficients among the primary components of the Penta BDE formulations  
296 at Point Petre, Burnt Island and Egbert. The primary components of the PentaBDE technical mixtures are  
297 significantly ( $p < 0.05$ ) correlated.

Point Petre	BDE-47	BDE-99	BDE-100
BDE-47	1.0		
BDE-99	0.68	1.0	
BDE-100	0.75	0.98	1.0
<b>Burnt Island</b>			
BDE-47	1.0		
BDE-99	0.96	1.0	
BDE-100	0.96	0.99	1.0
<b>Egbert</b>			
BDE-47	1.0		
BDE-99	0.99	1.0	
BDE-100	0.99	0.99	1.0

298  
299  
300  
301  
302  
303  
304

305 **Table S5.** Ratios between BDE-47 and -99, BDE-99 and -100 and anti-DDC-CO and total DDC-CO in Great  
 306 Lakes air

	Burnt Island	Egbert	Point Petre
<b>BDE-47/BD-E99</b>			
2005	2.2	2.4	2.2
2006	1.7	1.9	2.2
2007	2.7	2.2	2.0
2008	2.8	1.3	1.7
2009	2.1		2.2
2010	1.6		1.4
2011	2.4		1.5
2012	3.0		1.9
2013	0.9		2.0
2014			3.3
<b>BDE-99/BDE-100</b>			
2005	4.6	4.1	4.2
2006	4.5	4.4	5.2
2007	5.5	4.1	6.1
2008	4.4	4.7	3.8
2009	4.0		3.6
2010	4.4		4.2
2011	4.0		4.4
2012	3.5		4.3
2013	4.7		6.0
2014			4.1
<b>anti-DDC-CO/Total DDC-CO</b>			
2008	0.72		0.67
2009	0.72		0.76
2010	0.76		0.79
2011	0.68		0.79
2012	0.80		0.68
2013	0.79		0.84
2014			0.74

307

308

309

310

311

312 **Table S6.** Regression results from the one-parameter non-linear model

Sampling period	$A \times 10^5$	$R^2$
04-02-2005	0.42	0.40
17-04-2005	1.2	0.98
11-05-2005	0.94	0.99
04-06-2005	0.25	0.99
28-06-2005	0.00015	0.31
10-07-2005	0.22	0.99
22-07-2005	0.79	0.98
03-08-2005	0.33	0.98
15-08-2005	0.097	0.99
27-08-2005	0.087	0.99
08-09-2005	0.10	0.99
20-09-2005	0.15	0.99
02-10-2005	0.15	0.99
14-10-2005	0.049	0.99
25-12-2005	0.79	0.03
30-05-2005	0.054	0.23
23-06-2006	0.069	0.99
17-07-2006	0.29	0.95
29-07-2006	0.13	0.33
10-08-2006	0.093	0.99
15-09-2006	0.13	0.99
09-10-2006	0.20	0.95
24-07-2007	0.13	0.89
05-08-2007	0.0016	0.99
22-09-2007	0.34	0.97
13-02-2008	0.0016	0.19
25-02-2008	0.23	0.55
08-03-2008	0.20	0.58
20-03-2008	3.5	0.89
01-04-2008	3.6	0.87
25-04-2008	0.25	0.75
07-05-2008	0.53	0.90
19-05-2008	0.0012	0.91
31-05-2008	1.7	0.87
24-06-2008	0.67	0.90
06-07-2008	1.1	0.90
18-07-2008	1.4	0.75
30-07-2008	0.019	0.46
12-08-2008	0.019	0.46

Sampling period	$A \times 10^5$	$R^2$
23-08-2008	0.65	0.97
04-09-2008	0.012	0.76
28-09-2008	0.0085	0.96
22-10-2008	0.0012	0.83
03-11-2008	0.80	0.72
15-11-2008	0.81	0.86
27-11-2008	0.18	0.77
21-12-2008	0.044	0.74
07-02-2009	0.073	0.21
19-02-2009	0.23	0.68
15-03-2009	0.36	0.40
08-04-2009	0.0036	0.22
02-05-2009	0.015	0.87
14-05-2009	0.039	0.93
26-05-2009	0.00016	0.94
07-06-2009	0.27	0.79
19-06-2009	0.084	0.89
25-07-2009	0.40	0.86
06-08-2009	0.15	0.78
18-08-2009	0.30	0.95
30-08-2009	0.026	0.90
11-09-2009	0.50	0.63
23-09-2009	1.6	0.86
05-10-2009	0.50	0.78
17-10-2009	0.13	0.71
29-10-2009	0.22	0.62
10-11-2009	0.25	0.74
22-11-2009	0.074	0.18
04-12-2009	0.023	0.97
16-12-2009	0.0073	0.85
28-12-2009	0.17	0.82
09-01-2010	0.19	0.40
21-01-2010	0.018	0.10
02-02-2010	0.00030	0.85
14-02-2010	0.0023	0.73
26-02-2010	0.00032	0.92
10-03-2010	0.12	0.69
03-04-2010	0.31	0.92
15-04-2010	0.031	0.77
27-04-2010	0.0014	0.96

Sampling period	$A \times 10^5$	$R^2$
09-05-2010	0.0033	0.99
02-06-2010	2.9	0.23
14-06-2010	0.35	0.56
26-06-2010	0.43	0.38
08-07-2010	0.23	0.81
20-07-2010	0.12	0.87
13-08-2010	0.098	0.90
06-09-2010	0.16	0.96
18-09-2010	0.24	0.57
24-10-2010	0.0099	0.91
05-11-2010	0.061	0.62
17-11-2010	0.051	0.95
16-01-2011	0.033	0.93
05-03-2011	0.071	0.98
09-06-2011	0.36	0.99
03-07-2011	0.040	0.99
20-08-2011	0.67	0.99
13-09-2011	0.45	0.99
07-10-2011	0.038	0.17
31-10-2011	0.0038	0.93
18-12-2011	0.00016	0.84
11-01-2012	0.33	0.95
04-02-2012	0.089	0.30
28-02-2012	0.013	0.02
23-02-2012	0.012	0.98
16-04-2012	0.028	0.89
10-05-2012	0.22	0.87
03-06-2012	0.56	0.90
27-06-2012	1.2	0.57
14-08-2012	0.13	0.99
07-09-2012	0.63	0.85
01-10-2012	0.0055	0.99
25-10-2012	0.057	0.94
18-11-2012	0.051	0.82
12-12-2012	0.0027	0.02

313

314


315

316 **Table S7.** First order apparent half-lives ( $t_{1/2}$ ) of halogenated flame retardants at the three Canadian  
 317 Great Lakes sites.

	Burnt Island (2005-2013)	Burnt Island (2005-2013)	Point Petre (2005-2014)		Point Petre (2005-2014)	
BDEs	$t_{1/2}$ (year) $r^2$	$t_2$ (year) $r^2$	$t_{1/2}$ (year) $r^2$		$t_2$ (year) $r^2$	
BDE-17	8.1 0.75		8.1	0.43		
BDE-28	26 0.36		15	0.28		
BDE-47		23 0.39	7.2	0.62		
BDE-49	8.4 0.47		5.9	0.72		
BDE-99	13 0.44		6.6	0.85		
BDE-100		17 0.93	5.9	0.94		
BDE-153*	2.5 0.62				5.0	0.24
BDE-154*	1.8 0.81			0.95	5.7	0.24
BDE-209	5.7 0.96		16	0.12		
Total BDE		20 0.53	8.4	0.79		
non-PBDE HFRs	(2008-2013)	(2008-2013)	(2008-2014)		(2008-2014)	
<i>anti</i> -DDC-CO	3.4 0.36		13	0.11		
<i>syn</i> -DDC-CO		7.6 0.21	6.6	0.41		
TBP-AE	24 0.1				14	0.1
HBBz	27 0.11				11	0.33
PBT	2.1 0.99				7.6	0.55

\*Half-life was derived for BDE-153 and BDE-154 at Burnt Island from 2008 to 2013 and BDE-153 and BDE-154 at Point Petre from 2008 to 2014


351




352

353 **Figure S1.** Relative abundance of non-PBDE HFRs at Point Petre and Burnt Island.


354





359

360 **Figure S3.** Seasonal profiles of air concentrations of non-PBDE HFRs and ambient temperature at Burnt  
 361 Island. Blue shadings indicate summer period (April to September).



364 **Figure S4.** Seasonal cycles, trends and measurements of BDE-49, -100, -153 and -154 at Burnt Island and  
365 Point Petre.

- 372      **Literature Cited**
- 373      1. M. J. Guardia, R. C. Hale and E. Harvey, *Environ. Sci. Technol.*, 2006, **40**, 6247 – 6254.
- 374      2. Y. Su, H. Hung, K. A. Brice, K. Su, N. Alexandrou, P. Blanchard, E. Chan, E. Scerko, P. Fellin, *Atmos.*  
375      *Environ.*, 2007, **43**, 6230 – 6237.
- 376      3. L. Fang, J. Huang, G. Yu, L. Wang, *Chemosphere*, 2008, **71**, 258 – 267.
- 377      4. F. Wania and C. B. Dugani, *Environ. Toxicol. Chem.*, 2003, **22**, 1252 – 1261.
- 378      5. E. Hoh, L. Zhu and R. A. Hites, *Environ. Sci. Technol.*, 2006, **40**, 1184 – 1189.
- 379      6. M. Vernier and R. A. Hites, *Environ. Sci. Technol.*, 2008, **42**, 4745 – 4751.
- 380      7. A. Salamova and R. A. Hites, *Environ. Sci. Technol.*, 2011, **45**, 9924 – 9930.
- 381      8. Y. Su, Y. D. Lei, F. Wania, M. Shoeib, T. Harner, *Environ. Sci. Technol.*, 2006, **40**, 3558 – 3564.
- 382      9. J. F. Pankow, *Atmos. Environ.*, 1987, **21**, 2275 – 2283.
- 383      10. S. A. Tittlemier, T. Halldorson, G. A. Stern, G. T. Tomy, *Environ. Toxicol. Chem.*, 2002, **21**, 1804 –  
384      1810.
- 385      11. T. F. Bidleman, *Environ. Sci. Technol.*, 1998, **22**, 361 – 367.
- 386      12. J. F. Pankow, *Atmos. Environ.*, 1994, **28**, 185 – 188.
- 387

388