

## Supplementary information

**Step-by-step analysis of drinking water treatment trains using size-exclusion chromatography to fingerprint and track protein-like and humic/fulvic-like fractions of dissolved organic matter**

Alexey Ignatev, Tuula Tuhkanen


Department of Biological and Environmental Science, University of Jyväskylä  
PO Box 35, FI-40014, Jyväskylä, Finland

[alexey.n.ignatev@jyu.fi](mailto:alexey.n.ignatev@jyu.fi), [alexignat@gmail.com](mailto:alexignat@gmail.com) (A. Ignatev)


[tuula.a.tuhkanen@jyu.fi](mailto:tuula.a.tuhkanen@jyu.fi) (T. Tuhkanen)

## Table of contents


Fig. S1 .....	.3
Fig. S2 .....	.4
Fig. S3 .....	.5
Fig. S4 .....	.6
Fig. S5 .....	.7
Fig. S6 .....	.8
Fig. S7 .....	.9
Fig. S8 .....	.10
Fig. S9 .....	.11
Table S1 .....	.12
Table S2 .....	.13
Table S3 .....	.14
Table S4 .....	.15
Table S5a-c .....	.16
Table S6a-c .....	.17




**Fig. S1.** Typical EEM fluorescence spectrum of a raw water (sampled from lake Päijänne, Finland, on 10.07.2018). Regions corresponding to tyrosine-like (B<sub>1</sub>, B<sub>2</sub>), tryptophan-like (T<sub>1</sub>, T<sub>2</sub>) and humic/fulvic-like (A, C<sub>1</sub>, C<sub>2</sub>) fluorescence are indicated with white triangles.




**Fig. S2.** Comparison of HPSEC chromatograms demonstrating influence of excitation wavelength on intensity of tyrosine-like fluorescence (emission at 310 nm) of a raw water (sampled from lake Konnevesi, Finland, on 14.03.2017). Overlapping with Raman scatter peak of water led to higher noise of fluorescence signal at 270/310 nm compared to 220/310 nm (note degraded peak II).




**Fig. S3.** Calibration of the size-exclusion column using acetone, polystyrene sulphonate (PSS) standards, and blue dextran. The fitting equation was used to calculate apparent MW of DOM fractions and estimate  $M_w$  and  $M_n$ .




**Fig. S4.** Characterization of DOM at DWTP B. Left column: superimposed HPSEC chromatograms of raw water and treated water with (a)-(d) fluorescence and (e)-(f) UV detection. Right column: evolution of DOM fractions I-VI along the water treatment train (mean area  $\pm$  SD,  $n = 4$ ).




**Fig. S5.** Relative abundance of fluorescing and UV absorbing DOM fractions I-VI in raw water (B1), process water (B2-B5), and treated water (B6) at DWTP B (mean  $\pm$  SD,  $n = 4$ ). Locations of sampling points B1-B6 are shown in Fig. 1.




**Fig. S6.** Step-by-step, fraction-by-fraction, and overall efficiency of DWTP B (mean  $\pm$  SD,  $n = 4$ ). Absent or removed fractions are denoted with ‘X’. Negative removal efficiencies indicate formation of DOM (during chlorination)



**Fig. S7.** Ratio  $\text{UVA}_{210}/\text{UVA}_{254}$  of DOM fractions and whole water samples from DWTP B (mean  $\pm$  SD,  $n = 4$ ). Lower values indicate higher aromatic character. Removed in the coagulation/flocculation high MW fraction I is denoted with “X”.



**Fig. S8.** Correlation between removal efficiencies by coagulation and ratio  $\text{UVA}_{210}/\text{UVA}_{254}$  of DOM fractions II-VI for (a) DWTP A and (b) DWTP B.



**Fig. S9.** Decline of AC filtration efficiency at DWTP A over time in regards to removal of fluorescing and UV absorbing DOM fractions IV-VI. Each point represents a single sample of AC filtration effluent collected from one of the eight parallel AC tanks. The linear trend lines were calculated using robust regression (MATLAB *robustfit*, bisquare weight function),  $\rho$  is Pearson correlation coefficient ( $n = 38$ ).

**Table S1.** Main parameters of the HPSEC-UV-fluorescence method.

Eluent flow rate	1 mL min <sup>-1</sup>
Injection volume	50 µL
Autosampler temperature	4 °C
Column oven temperature	25 °C
Elution time	30 min
<i>PDA detector</i>	
Wavelength range	200-400 nm
Cell temperature	40 °C
Slit width	1.2 nm
Data acquisition rate	4.17 Hz
<i>Fluorescence detector</i>	
$\lambda_{\text{ex}}/\lambda_{\text{em}}$	220/310 nm (tyrosine-like) 270/355 nm (tryptophan-like) 330/425 nm (humic/fulvic-like) 390/500 nm (humic/fulvic-like)
Cell temperature	25 °C
Sensitivity	High
Gain	1×
Data acquisition rate	5.00 Hz

**Table S2.** Water quality parameters at DWTP A in 2017 (*n* is the total number of analyses of raw and treated waters).\*

	Raw water (A1)			Treated water (A7)			<i>n</i> (raw/treated)
	Mean	Min	Max	Mean	Min	Max	
Temperature (°C)	<b>10.3</b>	2.2	18.3	<b>10.2</b>	3.6	15.0	51/24
pH	<b>7.3</b>	7.8	7.0	<b>8.4</b>	8.1	9.0	51/111
Alkalinity (mmol L <sup>-1</sup> )	<b>0.46</b>	0.41	0.49	<b>0.63</b>	0.56	0.72	12/12
Hardness (mmol L <sup>-1</sup> )	<b>0.22</b>	0.22	0.22	<b>0.40</b>	0.39	0.42	12/12
Turbidity (FNU)	<b>2.2</b>	1.4	3.8	<b>0.09</b>	0.05	0.11	51/84
Conductivity (mS/m)	<b>7.1</b>	6.3	10.9	<b>12.1</b>	11.7	14.3	51/75
TOC (mg L <sup>-1</sup> )	<b>6.8</b>	6.3	7.7	<b>1.8</b>	1.6	2.5	12/12
NH <sub>4</sub> -N (µg L <sup>-1</sup> )	<b>n.d.</b>	<i>n.d.</i>	<i>n.d.</i>	<b>0.11</b>	0.08	0.14	0/12
Cl <sub>2</sub> (mg L <sup>-1</sup> )	<b>n.d.</b>	<i>n.d.</i>	<i>n.d.</i>	<b>0.34</b>	0.19	0.41	0/120
Al (mg L <sup>-1</sup> )	<b>0.00</b>	0.00	0.00	<b>0.02</b>	0.00	0.06	3/48
Fe (mg L <sup>-1</sup> ) <sup>†</sup>	<b>0.197</b>	0.197	0.197	<b>0.005</b>	0.000	0.023	3/24
Mn (mg L <sup>-1</sup> ) <sup>‡</sup>	<b>0.085</b>	0.085	0.085	<b>0.003</b>	0.000	0.009	3/24

\* The data were provided by DWTP A.

<sup>†</sup> In 2018, the concentration of Fe was 0.158 mg L<sup>-1</sup>.

<sup>‡</sup> In 2018, the concentration of Mn was 0.176 mg L<sup>-1</sup>.

**Table S3.** Water quality parameters measured at DWTP B in 2017 (*n* is the total number of analyses of raw and treated waters).\*

	Raw water (B1)			Treated water (B6)			<i>n</i> (raw/treated)
	Mean	Min	Max	Mean	Min	Max	
Temperature (°C)	<b>7.8</b>	0.5	18.7	<b>8.0</b>	0.8	19.0	249/249
pH	<b>7.2</b>	6.9	7.7	<b>8.2</b>	7.9	8.5	248/249
Alkalinity (mmol L <sup>-1</sup> )	<b>0.28</b>	0.26	0.29	<b>0.69</b>	0.61	0.76	54/249
Hardness (°dH)	<b>1.1</b>	1.0	1.2	<b>3.4</b>	3.2	3.6	52/52
Hardness (mmol L <sup>-1</sup> )	<b>0.20</b>	0.18	0.21	<b>0.61</b>	0.57	0.64	52/52
Turbidity (NTU)	<b>2.1</b>	0.27	11	<b>0.05</b>	0.03	0.09	249/249
Conductivity (mS/m)	<b>6.3</b>	6.1	6.5	<b>15.1</b>	14.7	15.5	51/51
UVA <sub>254</sub> (AU)	<b>0.139</b>	0.128	0.159	<b>0.024</b>	0.013	0.30	22/20
TOC (mg L <sup>-1</sup> )	<b>6.1</b>	5.8	6.3	<b>2.2</b>	1.6	2.7	51/248
Total N (µg L <sup>-1</sup> )	<b>350</b>	310	380	<b>170</b>	110	220	6/6
NH <sub>4</sub> -N (µg L <sup>-1</sup> )	<b>7</b>	2	15	<b>2</b>	2	3	7/7
NO <sub>3</sub> -N (mg L <sup>-1</sup> )	< <b>0.10</b>	< 0.10	< 0.10	< <b>0.10</b>	< 0.10	< 0.10	7/7
NO <sub>2</sub> -N (mg L <sup>-1</sup> )	< <b>1</b>	< 1	1	< <b>1</b>	< 1	< 1	7/7
Total P (µg L <sup>-1</sup> )	<b>14</b>	10	18	< <b>3</b>	< 2	6	8/8
Cl <sub>2</sub> (mg L <sup>-1</sup> )	<b>n.d.</b>	<i>n.d.</i>	<i>n.d.</i>	<b>0.44</b>	0.38	0.50	0/249
Al (mg L <sup>-1</sup> )	< <b>0.03</b>	< 0.02	0.07	< <b>0.02</b>	< 0.02	0.03	7/8
Fe (mg L <sup>-1</sup> )	< <b>0.10</b>	< 0.02	0.25	< <b>0.02</b>	< 0.02	< 0.02	52/248
Mn (mg L <sup>-1</sup> )	< <b>0.03</b>	< 0.01	0.05	< <b>0.01</b>	< 0.01	< 0.01	7/48

\* The data are published online at  
[https://www.tampere.fi/material/attachments/vesi/vesi/bOKLI2SYI/Ruskon\\_kayttotarkkailu\\_2017.pdf](https://www.tampere.fi/material/attachments/vesi/vesi/bOKLI2SYI/Ruskon_kayttotarkkailu_2017.pdf).

**Table S4.** Characteristics of whole water at different steps of DWTP B (mean  $\pm$  SD,  $n = 4$ ).

	B1 Raw water	B2 Flotation effluent	B3 Chlorination effluent	B4 Sand filtration effluent	B5 AC filtration effluent	B6 Treated water
DOC (mg L <sup>-1</sup> )	6.3 $\pm$ 0.5	2.7 $\pm$ 0.2	2.7 $\pm$ 0.1	2.7 $\pm$ 0.2	2.3 $\pm$ 0.3	2.3 $\pm$ 0.2
SUVA (L mg <sup>-1</sup> m <sup>-1</sup> )	2.5 $\pm$ 0.3	1.5 $\pm$ 0.4	1.6 $\pm$ 0.5	1.4 $\pm$ 0.2	1.4 $\pm$ 0.3	1.1 $\pm$ 0.2
UVA <sub>210</sub> /UVA <sub>254</sub>	2.1 $\pm$ 0.2	2.9 $\pm$ 0.6	2.8 $\pm$ 0.5	2.9 $\pm$ 0.5	3.5 $\pm$ 0.5	4.1 $\pm$ 0.6
Total UV absorbance (mAU min)						
254 nm	7.8 $\pm$ 0.8	2.0 $\pm$ 0.5	2.1 $\pm$ 0.7	1.9 $\pm$ 0.3	1.6 $\pm$ 0.3	1.3 $\pm$ 0.2
210 nm	16.3 $\pm$ 1.4	5.9 $\pm$ 1.0	5.9 $\pm$ 0.7	5.9 $\pm$ 0.9	5.4 $\pm$ 1.1	5.2 $\pm$ 1.1
Total fluorescence (mV min)						
Tyrosine-like (220/310 nm)	33.8 $\pm$ 3.1	13.2 $\pm$ 2.5	9.9 $\pm$ 2.6	12.3 $\pm$ 2.6	9.7 $\pm$ 2.9	7.8 $\pm$ 1.0
Tryptophan-like (270/355 nm)	62.5 $\pm$ 5.4	26.1 $\pm$ 3.3	25.8 $\pm$ 3.5	25.5 $\pm$ 3.5	16.7 $\pm$ 2.7	14.5 $\pm$ 2.5
Humic/fulvic-like (330/425 nm)	149.3 $\pm$ 19.1	52.2 $\pm$ 8.9	54.0 $\pm$ 10.1	52.8 $\pm$ 8.3	31.1 $\pm$ 7.6	30.3 $\pm$ 6.1
Humic/fulvic-like (390/500 nm)	38.7 $\pm$ 4.4	10.6 $\pm$ 1.5	11.0 $\pm$ 1.7	10.9 $\pm$ 1.3	6.8 $\pm$ 1.6	5.8 $\pm$ 1.2

**Table S5a.** Number average MW DWTP A (mean  $\pm$  SD,  $n=3$ ).

	A1 Raw water	A2 Ozonation effluent	A3 Flotation effluent	A4 Sand filtration effluent	A5 Chlorination effluent	A6 AC filtration effluent	A7 Treated water
UV detection							
254 nm	803 $\pm$ 99	788 $\pm$ 49	460 $\pm$ 60	395 $\pm$ 71	411 $\pm$ 64	428 $\pm$ 37	467 $\pm$ 42
210 nm	789 $\pm$ 60	735 $\pm$ 46	411 $\pm$ 31	386 $\pm$ 25	386 $\pm$ 18	380 $\pm$ 13	371 $\pm$ 13
Fluorescence detection							
Tyrosine-like (220/310 nm)	433 $\pm$ 32	442 $\pm$ 42	327 $\pm$ 36	318 $\pm$ 34	316 $\pm$ 38	349 $\pm$ 45	342 $\pm$ 39
Tryptophan-like (270/355 nm)	474 $\pm$ 46	497 $\pm$ 46	329 $\pm$ 36	317 $\pm$ 35	317 $\pm$ 38	381 $\pm$ 42	373 $\pm$ 42
Humic/fulvic-like (330/425 nm)	513 $\pm$ 58	576 $\pm$ 56	336 $\pm$ 39	326 $\pm$ 39	332 $\pm$ 40	412 $\pm$ 43	406 $\pm$ 44
Humic/fulvic-like (390/500 nm)	605 $\pm$ 58	657 $\pm$ 60	375 $\pm$ 45	359 $\pm$ 42	367 $\pm$ 44	442 $\pm$ 46	435 $\pm$ 50

**Table S5b.** Weight average MW DWTP A (mean  $\pm$  SD,  $n=3$ ).

	A1 Raw water	A2 Ozonation effluent	A3 Flotation effluent	A4 Sand filtration effluent	A5 Chlorination effluent	A6 AC filtration effluent	A7 Treated water
UV detection							
254 nm	1398 $\pm$ 98	1486 $\pm$ 359	609 $\pm$ 88	567 $\pm$ 60	610 $\pm$ 42	705 $\pm$ 107	653 $\pm$ 29
210 nm	1378 $\pm$ 104	1377 $\pm$ 283	573 $\pm$ 44	528 $\pm$ 38	576 $\pm$ 29	573 $\pm$ 44	550 $\pm$ 38
Fluorescence detection							
Tyrosine-like (220/310 nm)	925 $\pm$ 143	912 $\pm$ 141	547 $\pm$ 79	500 $\pm$ 48	500 $\pm$ 25	605 $\pm$ 63	509 $\pm$ 43
Tryptophan-like (270/355 nm)	850 $\pm$ 37	896 $\pm$ 117	463 $\pm$ 53	435 $\pm$ 29	428 $\pm$ 41	520 $\pm$ 42	522 $\pm$ 37
Humic/fulvic-like (330/425 nm)	857 $\pm$ 45	965 $\pm$ 148	463 $\pm$ 51	438 $\pm$ 46	451 $\pm$ 45	556 $\pm$ 32	558 $\pm$ 33
Humic/fulvic-like (390/500 nm)	996 $\pm$ 46	1114 $\pm$ 190	525 $\pm$ 61	494 $\pm$ 46	507 $\pm$ 43	601 $\pm$ 38	603 $\pm$ 33

**Table S5c.** Dispersities DWTP A (mean  $\pm$  SD,  $n=3$ ).

	A1 Raw water	A2 Ozonation effluent	A3 Flotation effluent	A4 Sand filtration effluent	A5 Chlorination effluent	A6 AC filtration effluent	A7 Treated water
UV detection							
254 nm	1.76 $\pm$ 0.27	1.88 $\pm$ 0.42	1.32 $\pm$ 0.03	1.45 $\pm$ 0.20	1.50 $\pm$ 0.22	1.67 $\pm$ 0.41	1.41 $\pm$ 0.14
210 nm	1.76 $\pm$ 0.22	1.87 $\pm$ 0.29	1.39 $\pm$ 0.06	1.37 $\pm$ 0.08	1.50 $\pm$ 0.14	1.51 $\pm$ 0.16	1.48 $\pm$ 0.14
Fluorescence detection							
Tyrosine-like (220/310 nm)	2.16 $\pm$ 0.44	2.08 $\pm$ 0.38	1.68 $\pm$ 0.22	1.58 $\pm$ 0.22	1.59 $\pm$ 0.13	1.76 $\pm$ 0.33	1.49 $\pm$ 0.06
Tryptophan-like (270/355 nm)	1.81 $\pm$ 0.20	1.81 $\pm$ 0.24	1.41 $\pm$ 0.10	1.38 $\pm$ 0.06	1.35 $\pm$ 0.03	1.37 $\pm$ 0.04	1.40 $\pm$ 0.06
Humic/fulvic-like (330/425 nm)	1.68 $\pm$ 0.14	1.68 $\pm$ 0.21	1.38 $\pm$ 0.07	1.34 $\pm$ 0.05	1.36 $\pm$ 0.03	1.36 $\pm$ 0.06	1.38 $\pm$ 0.07
Humic/fulvic-like (390/500 nm)	1.66 $\pm$ 0.15	1.70 $\pm$ 0.25	1.40 $\pm$ 0.07	1.38 $\pm$ 0.07	1.38 $\pm$ 0.04	1.36 $\pm$ 0.05	1.39 $\pm$ 0.09

**Table S6a.** Number average MW DWTP B (mean  $\pm$  SD,  $n=4$ ).

	B1 Raw water	B2 Flotation effluent	B3 Chlorination effluent	B4 Sand filtration effluent	B5 AC filtration effluent	B6 Treated water effluent
UV detection						
254 nm	766 $\pm$ 88	384 $\pm$ 34	413 $\pm$ 34	415 $\pm$ 34	444 $\pm$ 37	440 $\pm$ 27
210 nm	593 $\pm$ 44	321 $\pm$ 15	339 $\pm$ 20	339 $\pm$ 20	333 $\pm$ 21	334 $\pm$ 20
Fluorescence detection						
Tyrosine-like (220/310 nm)	442 $\pm$ 10	295 $\pm$ 15	314 $\pm$ 16	303 $\pm$ 31	339 $\pm$ 36	332 $\pm$ 22
Tryptophan-like (270/355 nm)	460 $\pm$ 5	293 $\pm$ 14	311 $\pm$ 12	311 $\pm$ 9	355 $\pm$ 32	357 $\pm$ 27
Humic/fulvic-like (330/425 nm)	506 $\pm$ 20	302 $\pm$ 20	320 $\pm$ 10	326 $\pm$ 13	379 $\pm$ 27	398 $\pm$ 26
Humic/fulvic-like (390/500 nm)	586 $\pm$ 23	331 $\pm$ 27	361 $\pm$ 13	368 $\pm$ 16	436 $\pm$ 37	449 $\pm$ 31

**Table S6b.** Weight average MW DWTP B (mean  $\pm$  SD,  $n=4$ ).

	B1 Raw water	B2 Flotation effluent	B3 Chlorination effluent	B4 Sand filtration effluent	B5 AC filtration effluent	B6 Treated water effluent
UV detection						
254 nm	1348 $\pm$ 82	598 $\pm$ 95	655 $\pm$ 71	662 $\pm$ 36	692 $\pm$ 64	679 $\pm$ 37
210 nm	1160 $\pm$ 92	437 $\pm$ 46	497 $\pm$ 57	501 $\pm$ 33	500 $\pm$ 84	484 $\pm$ 44
Fluorescence detection						
Tyrosine-like (220/310 nm)	859 $\pm$ 164	413 $\pm$ 51	455 $\pm$ 36	445 $\pm$ 59	526 $\pm$ 79	501 $\pm$ 55
Tryptophan-like (270/355 nm)	790 $\pm$ 60	392 $\pm$ 33	444 $\pm$ 20	446 $\pm$ 16	519 $\pm$ 50	520 $\pm$ 45
Humic/fulvic-like (330/425 nm)	818 $\pm$ 46	397 $\pm$ 43	448 $\pm$ 22	459 $\pm$ 26	536 $\pm$ 40	571 $\pm$ 41
Humic/fulvic-like (390/500 nm)	944 $\pm$ 60	451 $\pm$ 55	529 $\pm$ 27	540 $\pm$ 30	630 $\pm$ 51	656 $\pm$ 44

**Table S6c.** Dispersities DWTP B (mean  $\pm$  SD,  $n=4$ ).

	B1 Raw water	B2 Flotation effluent	B3 Chlorination effluent	B4 Sand filtration effluent	B5 AC filtration effluent	B6 Treated water effluent
UV detection						
254 nm	1.78 $\pm$ 0.25	1.58 $\pm$ 0.36	1.59 $\pm$ 0.24	1.60 $\pm$ 0.14	1.57 $\pm$ 0.23	1.54 $\pm$ 0.05
210 nm	1.96 $\pm$ 0.15	1.36 $\pm$ 0.12	1.46 $\pm$ 0.11	1.48 $\pm$ 0.06	1.50 $\pm$ 0.17	1.45 $\pm$ 0.05
Fluorescence detection						
Tyrosine-like (220/310 nm)	1.94 $\pm$ 0.34	1.39 $\pm$ 0.11	1.45 $\pm$ 0.05	1.46 $\pm$ 0.05	1.55 $\pm$ 0.21	1.51 $\pm$ 0.11
Tryptophan-like (270/355 nm)	1.72 $\pm$ 0.14	1.34 $\pm$ 0.05	1.43 $\pm$ 0.02	1.43 $\pm$ 0.02	1.46 $\pm$ 0.04	1.46 $\pm$ 0.04
Humic/fulvic-like (330/425 nm)	1.62 $\pm$ 0.09	1.31 $\pm$ 0.05	1.40 $\pm$ 0.03	1.41 $\pm$ 0.03	1.41 $\pm$ 0.04	1.44 $\pm$ 0.04
Humic/fulvic-like (390/500 nm)	1.61 $\pm$ 0.11	1.36 $\pm$ 0.06	1.47 $\pm$ 0.05	1.47 $\pm$ 0.03	1.45 $\pm$ 0.07	1.46 $\pm$ 0.04