

## Screen versus cyclone for improved capacity and robustness for sidestream and mainstream deammonification

*Tim Van Winckel*<sup>a,b,c</sup>, *Siegfried E. Vlaeminck*<sup>a,d\*</sup>, *Ahmed Al-Omari*<sup>b</sup>, *Benjamin Bachmann*<sup>e</sup>,  
*Belinda Sturm*<sup>c</sup>, *Bernhard Wett*<sup>f</sup>, *Imre Takács*<sup>g</sup>, *Charles Bott*<sup>h</sup>, *Sudhir N. Murthy*<sup>i</sup> and *Haydée De Clippeleir*<sup>b</sup>

<sup>a</sup> *Center of Microbial Ecology and Technology (CMET), Faculty of Bioscience Engineering, Ghent University, Ghent, Belgium*

<sup>b</sup> *District of Columbia Water and Sewer Authority, Blue Plains Advanced Wastewater Treatment Plant, 5000 Overlook Ave, SW Washington, DC 20032, USA*

<sup>c</sup> *Department of Civil, Environmental and Architectural engineering, The University of Kansas, KS, USA*

<sup>d</sup> *Research Group of Sustainable Energy, Air and Water Technology, Department of Bioscience Engineering, University of Antwerp, Antwerpen, Belgium*

<sup>e</sup> *Department of Microbiology; University of Innsbruck, Austria*

<sup>f</sup> *ARA consult GmbH, Innsbruck, Austria*

<sup>g</sup> *Dynamita SARL, France*

<sup>h</sup> *Hampton Roads Sanitation District, VA, USA*

<sup>i</sup> *New Hub, VA, USA*

\* *Corresponding author: [siegfried.vlaeminck@uantwerpen.be](mailto:siegfried.vlaeminck@uantwerpen.be)*

## Supplemental D:

**Table D1.** Kinetic parameters used in model. Adapted from the calibrated model in Al-Omari et al. (2015).

<b>Parameter</b>	<b>Unit</b>	<b>AOB</b>	<b>NOB</b>	<b>AnAOB</b>
$\mu_{max}$	$d^{-1}$	0.9	0.7	0.1
$K_{NH_4}$	$mg\ N\ L^{-1}$	0.7	-	0.5
$K_{NO_2}$	$mg\ N\ L^{-1}$	-	0.05	0.5
$K_o$	$mg\ O_2\ L^{-1}$	0.4 (0.25)	0.14 (0.5)	-
$d_{aer}$	$d^{-1}$	0.17	0.17	0.019
$d_{an}$	$d^{-1}$	0.08	0.08	0.0095