

Supplementary File for:

Spatial variation of loose deposits characteristics in a 40 km long operational drinking water distribution system

Xu Ma^a, Guiwei Li^{b,c}, Ying Yu^{b,c}, Ruya Chen^{b,c}, Yao Zhang^b, Hui Tao^d, Guangming Zhang^{a*}, Baoyou Shi^{b,c*}

^aSchool of Environment & Natural Resource, Renmin University of China, Beijing, 100872, China.

^bKey Laboratory of Drinking Water Science and Technology, Research Center for Eco-Environmental Sciences, Chinese Academy of Sciences, Beijing, 100085, China.

^cUniversity of Chinese Academy of Sciences, Beijing 100049, China

^dCollege of Environmental Science and Engineering, Hohai University, Nanjing 210098, China

CONTENTS

Table S1. Treated water quality parameters

Table S2. Location, type and manufacturers each flow meter

Table S3. Elemental composition (weight %) of the pipe deposits collected along the pipeline

Table S4. The normal flow rates at different flushing sites

Table S5. Concentration of heavy metals in flush water collected from different locations

Table S6. The bacterial community diversities of the samples collected from flush water or tap water

Table S7. ANOSIM statistics for flush water samples

Table S8. Relative abundance of opportunistic pathogen-containing genera collected from flushed water and tap water samples

Table S9. The quality parameters of treated water and tap water (before and after flushing)

Fig. S1. XRD patterns of flushing solid sample 0, 1 and 3

Fig. S2. Heatmaps showing the percentages of the top 30 abundant species at genus level for (a) tap water and (b) flushed water samples

Fig. S3. Distance calculated on genus level on each flush water sample group

Fig. S4. Microbial species with significant differences in the different flushed water samples

Fig. S5. Canonical Correlation Analysis (CCA) of bacteria community with tap water quality

Fig. S6. The residual chlorine values of treated water and 5 sites tap water

Table S1

Treated water quality parameters

Parameters	Treated water
T (°C, average)	24.6
pH	7.44
Turbidity (NTU)	0.14
Chlorine (mg/L as Cl ₂)	0.57
Alkalinity (mg/L CaCO ₃)	53.2
Hardness (mg/L CaCO ₃)	92.9
Chloride (mg/L)	11.3
Nitrate (mg/L)	1.41
Sulfate (mg/L)	24.5
COD _{mn} (mg/L)	0.87
Fe (mg/L)	<0.05
Mn (mg/L)	<0.03
Al (mg/L)	0.054
COD _{mn} : Chemical Oxygen Demand	

Table S2

Location, type and manufacturers of each flow meter

	Location	Type	Manufacturers
1	Within the water treatment plant	FXE4000	Shanghai ABB Engineering Co., Ltd.
2	site a	IFC050W	Shanghai Guanghai Altometer Instruments Co.,Ltd.
3	The front of site 3	IFC100W	Shanghai Guanghai Altometer Instruments Co.,Ltd.
4	site b	FXE4000	Shanghai ABB Engineering Co., Ltd.
5	site c	FXE4000	Shanghai ABB Engineering Co., Ltd.
6	site d	FEP	Shanghai ABB Engineering Co., Ltd.
7	site e	7ME5033	Siemens Ltd., China

Table S3

Elemental composition (weight %) of the pipe deposits collected along the pipeline

El	0	1-1	1-2	2-1	2-2	3-1	3-2	4-1	4-2	5-1	6-1	6-2	7-1	7-2	8-1	8-2	Mean
Si	6.91	4.49	4.84	29.02	31.46	8.02	13.13	26.63	25.64	25.21	30.15	27.75	27.9	29.21	23.0	26.84	21.57
Al	13.01	13.10	12.62	7.76	8.63	14.04	11.81	10.65	8.07	9.81	7.73	8.34	8.33	7.82	9.28	8.23	10.32
Mn	13.83	20.88	22.48	0.91	1.48	13.81	9.61	1.08	0.69	2.1	0.7	0.46	0.47	0.24	2.52	0.58	5.57
Fe	6.13	1.27	1.79	5.39	4.58	2.68	3.49	8.57	6.48	4.58	4.64	6.24	5.58	5.27	4.84	6.64	4.68
K	0.48	0.28	0.3	2.09	2.21	0.58	0.84	2.33	0.06	2.01	2.18	2.04	2.61	2.12	1.77	2.24	1.51
Ca	1.88	1.50	1.63	1.41	1.33	1.43	1.37	1.73	1.36	1.24	1.33	1.16	1.43	1.26	1.28	1.22	1.41
Ti	0.985	0.0909	0.127	0.722	0.865	0.208	0.349	0.916	0.676	0.694	0.654	0.87	0.779	0.748	0.738	0.836	0.6199
Mg	0.70	0.50	0.64	0.57	0.47	0.45	0.4	0.89	0.70	0.6	0.62	0.54	0.69	0.61	0.52	0.64	0.6
Na	0.16	0.10	-	0.45	0.38	0.22	0.03	0.21	0.25	0.34	0.48	0.23	0.63	0.3	0.24	0.24	0.27
Cl	0.741	0.256	0.104	0.132	0.0977	0.419	0.164	0.025	0.021	0.181	0.0632	-	0.273	-	0.237	-	0.2126
S	0.239	0.205	0.226	0.0821	0.0771	0.174	0.128	0.115	0.0878	0.0717	0.0291	-	0.0377	0.0138	0.132	0.0155	0.1209
P	0.104	0.115	0.0895	0.0662	0.12	0.143	0.143	0.126	0.0865	0.116	0.0703	0.0479	0.0915	0.0658	0.181	0.0847	0.1158
Zn	0.121	0.139	0.138	0.038	0.036	0.202	0.156	0.112	0.069	0.059	0.038	0.051	0.028	0.040	0.12	0.073	0.085
Cu	0.047	0.074	0.059	-	-	0.079	0.038	-	-	0.01	0.003	-	-	-	-	-	0.044
Ni	0.061	0.089	0.08	0.007	-	0.09	0.055	-	-	0.015	0.008	-	0.008	-	0.006	-	0.038
La	-	0.0096	0.0149	0.0229	0.064	0.0132	0.046	0.0660	0.047	0.0136	-	-	0.0344	-	0.046	-	0.0344
Zr	-	-	0.0038	0.0334	0.0409	0.0058	-	0.0275	0.0269	-	0.0219	0.067	-	0.039	0.0272	0.0419	0.028
Sm	-	0.018	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0.018
Cr	-	-	-	0.0960	0.0066	0.0016	-	0.0205	0.0118	0.0079	0.0068	0.017	0.0096	0.0096	0.0093	0.0103	0.0156
Sr	-	0.012	0.016	0.017	0.018	0.011	0.011	-	0.017	0.011	0.017	-	0.018	0.022	0.014	0.022	0.015
V	-	0.013	0.017	0.011	0.014	0.011	0.015	0.018	0.013	0.012	0.011	0.023	0.015	0.016	0.017	0.019	0.014
Co	-	0.014	0.013	-	-	0.012	0.006	-	-	0.002	-	-	-	-	-	-	0.009
Ga	-	0.0042	-	0.0049	-	0.0026	-	0.0167	-	0.0032	0.0051	-	0.0044	-	0.0049	0.0143	0.0063
Y	-	-	-	0.0039	-	-	-	-	-	0.003	0.0029	-	-	-	-	-	0.0033

-: The element was not detected in this sample.

Table S4

The normal flow rates at different flushing sites

Flushing sites	Pipe diameter	Flow rate (m ³ /h)
1	DN 800	1400
2	DN 600	800
3	DN 500	200
4	DN 600	800
5	DN 600	500
6	DN 600	250
7	DN 400	250
8	DN 400	250

Table S5

Concentration of heavy metals in flush water collected from different locations

Element	Drinking	Flushing water samples																
	water																	
($\mu\text{g/L}$)	sandard	1-1	1-2	2-1	2-2	3-1	3-2	3-3	4-1	4-2	5-1	5-2	6-1	6-2	7-1	7-2	8-1	8-2
	($\mu\text{g/L}$)																	
Zn	1000	458.7	151.8	57.8	25.1	393.9	93.6	8.6	57.1	35.5	246.4	97.3	321.4	46.3	60.8	64.2	81.0	74.9
Cu	1000	242.9	64.4	0.0	0.0	153.1	22.9	0.0	0.0	0.0	42.1	0.0	22.3	0.0	0.0	0.0	0.0	0.0
Ni	20	294.0	87.8	10.4	0.0	175.5	32.7	1.4	0.0	0.0	60.5	3.6	67.7	0.0	17.6	0.0	4.3	0.0
Cr	50	0.0	0.0	146.9	4.6	3.1	0.0	0.3	10.5	6.1	32.9	7.1	58.3	15.6	20.6	15.5	6.3	10.5

“red numbers” means that they exceed the Drinking water standard

Table S6

The bacterial community diversities of the samples collected from flush water or tap water

Sample	OTU	Shannon	Simpson	Ace	Chao	Coverage
a-1	209	1.35	0.50	268.76	265	0.9972
b-1	175	2.01	0.24	384.29	272	0.9964
c-1	335	2.88	0.12	504.67	496	0.9943
d-1	230	2.97	0.14	235.08	240	0.9994
e-1	600	4.63	0.04	643.58	641	0.9967
1-2	515	3.32	0.09	631.11	634	0.9939
2-1	2011	5.81	0.05	2232.29	2241	0.9837
2-2	654	3.67	0.07	712.05	719	0.9952
3-1	708	3.11	0.14	1127.17	1025	0.9866
3-2	690	4.28	0.06	1144.14	1027	0.9899
4-1	1835	5.97	0.01	2238.28	2239	0.9790
4-2	2004	6.27	0.01	2420.10	2408	0.9778
5-1	920	1.89	0.40	1629.89	1482	0.9794
5-2	1304	5.31	0.02	1749.90	1735	0.9818
6-1	1206	2.71	0.27	1850.86	1789	0.9773
6-2	1186	3.58	0.12	1657.19	1550	0.9811
7-1	1230	3.60	0.14	1826.18	1795	0.9781
7-2	1428	3.66	0.17	2065.22	2070	0.9755
8-1	726	3.92	0.07	1309.91	1084	0.9879
8-2	1231	4.27	0.08	1849.28	1761	0.9789
a-2	277	1.80	0.44	374.15	361	0.9960
b-2	203	1.58	0.54	225.24	233	0.9984
c-2	188	1.58	0.47	208.02	205	0.9985
d-2	273	2.00	0.38	289.61	293	0.9984
e-2	574	3.44	0.12	720.58	739	0.9930

Table S7
ANOSIM statistics for flush water samples

Method	Statistic	P value	Permutation_number
ANOSIM	0.5743	0.003	999

Table S8

Relative abundance of opportunistic pathogen-containing genera collected from flushed water and tap water samples

	a	b	c	d	e	1	2	3	4	5	6	7	8
<i>Mycobacterium</i>	0.04	0.01	0.01	0.03	0.01	0.61	0.13	0.39	0.71	0.01	0.04	0.07	0.03
<i>Legionella</i>	0.04	0.01	0.02	0.19	0.25	0.78	0.01	0.27	0.27	0.01	0.03	0.03	0.06
<i>Pseudomonas</i>	0.19	0.07	0.05	0.1	0.57	0.41	0.14	0.18	1.39	0.02	0.03	0.89	1.01

Table S9

The quality parameters of treated water and tap water (before and after flushing)

	Turbidity (NTU)	residual chlorine (mg/L as Cl ₂)	Hardness (mg/L)	COD _{mn} (mg/L)	F ⁻ (mg/L)	Cl ⁻ (mg/L)	NO ₃ ⁻ (mg/L)	SO ₄ ²⁻ (mg/L)	HPC (CFU/ml)
TW-1	0.06	0.31	96.09	1.68	0.24	8.73	5.62	31.69	0
a-1	0.08	0.27	108.10	1.68	0.26	9.05	5.57	32.35	0
b-1	0.10	0.06	92.08	1.12	0.25	8.31	5.56	31.77	15
c-1	0.06	0.05	88.08	1.12	0.25	8.41	5.64	32.23	25
d-1	0.20	0.01	94.08	0.88	0.24	8.52	5.68	32.65	86
e-1	0.25	0.00	94.08	1.12	0.23	8.64	5.78	32.31	152
TW-2	0.08	0.34	92.08	1.04	0.24	8.32	5.36	33.60	0
a-2	0.10	0.3	94.08	1.04	0.24	9.03	5.67	37.03	0
b-2	0.11	0.27	100.09	0.8	0.25	9.94	5.89	35.19	0
c-2	0.10	0.12	134.12	0.96	0.36	9.32	5.68	35.91	2
d-2	0.25	0.11	102.09	1.04	0.27	9.56	5.68	36.14	1
e-2	0.28	0.00	100.09	1.04	0.36	8.80	5.63	35.74	15

COD_{mn}: Chemical Oxygen Demand, “-1” means before flushing, “-2” means after flushing






Fig. S1. XRD patterns of three typical deposits samples 0, 1 and 3 collected during the flushing process.



(a) flushed water



(b) tap water

Fig. S2. Heatmaps showing the percentages of the top 30 abundant species at genus level for (a) flushed water and (b) tap water samples




Fig. S3. Distance calculated on genus level on each flush water sample group




Fig. S4. Microbial species with significant differences in the different flushed water samples




Fig. S5. Canonical Correlation Analysis (CCA) of bacteria community with tap water quality




Fig. S6. The residual chlorine values of treated water and 5 sites tap water