

1

Electronic Supplementary Information

2

Efficacy of Corrosion Control and Pipe Replacement in Reducing Citywide Lead

3

Exposure during the Flint, MI Water System Recovery

4

5

Siddhartha Roy,^{1*} and Marc Edwards,¹

6

¹Department of Civil and Environmental Engineering, Virginia Tech

7

418 Durham Hall, 1145 Perry St.

8

Blacksburg, VA 24061, USA

9

10

* Corresponding author, Siddhartha Roy, email sidroy@vt.edu

11

12

13 **Text S1.** Estimating percentage of biosolids lead that will continue to be released from
 14 indoor plumbing (16-28%) and composite 90th percentile water lead levels (or, WLL90)
 15 (5.3-7.4 µg/L) after Flint replaces all lead and galvanized service lines by late 2020.

16 Equation 1: $Biosolids-Pb = (\% \text{ services remaining}) \times Pb_{services} + Pb_{indoor} +$
 17 Pb_{other}

18 **A.** We use the following equation from Roy et al., 2019 that relies on composite
 19 water lead levels from first and second draws:¹

20 Equation 2: $Biosolids-Pb \text{ (kg)} = 0.37 \times WLL90 \text{ (}\mu\text{g/L)} + 1.41$, where
 21 $WLL90 = \frac{1}{2} \times \text{first draw} + \frac{1}{2} \times \text{second draw}$ (Equation 2A)

Var.	Year	2013	2017	2018
A	Total Biosolids-Pb (kg)	117.7	77.6	72.9
B	% services remaining	100%	48%	34%
	• <i>Solving Equation 1 for both 2017 and 2018 against 2013 data</i>			
C	Pb_{services} (kg)	--	77.1	67.9
D	Pb_{indoor} + Pb_{other} (kg)	--	40.6	49.8
E	Pb_{other} (kg) for full year = 1.41 x 12 = 16.9 kg (from Equation 2)			
F	Pb_{indoor} (kg) = D – E	--	23.7	32.9
G	Percentage of Biosolids-Pb from plumbing = Pb_{indoor} / Total Biosolids-Pb or (F / A)	--	20.1%	28.0%
	<ul style="list-style-type: none"> • <i>Assuming Flint replaces all service lines by end of 2020, % of pipes in system = 0%.</i> • <i>Therefore, Total Biosolids-Pb = Pb_{indoor} + Pb_{other} (Equation 3)</i> • <i>Dividing Equation 3 by 12 months to get Biosolids-Pb/month, substituting Equation 3 in Equation 1: Pb_{plumbing+other} = 0.37 x WLL90 + 1.41, and solving for WLL90.</i> 			
H	WLL90 (µg/L)	--	5.3	7.4
I	Percentage WLL90 reduction against worst 3 FWC months (40.5 µg/L)	--	86.9%	81.7%
J	Percentage WLL90 reduction against pre-FWC year of 2013 (22.7 µg/L)	--	76.7%	67.4%

22 **II.** We also use the following equation from Roy et al., 2019 that relies on
 23 composite water lead levels from first, second, and third draws:¹

24 Equation 4: $Biosolids-Pb \text{ (kg/month)} = 0.483 \times WLL90 \text{ (}\mu\text{g/L)} + 1.79$,
 25 where $WLL90 = 1/3 \times \text{first draw} + 1/3 \text{ second draw} + 1/3 \text{ third draw}$
 26 (Equation 4A)


Var.	Year	2013	2017	2018
A	Total Biosolids-Pb (kg)	117.7	77.6	72.9
B	% services remaining	100%	48%	34%
	• Solving Equation 2 for both 2017 and 2018 against 2013 data			
C	Pb_{services} (kg)	--	77.1	67.9
D	Pb_{indoor} + Pb_{other} (kg)	--	40.6	49.8
E	Pb_{other} (kg) for full year = 1.79 x 12 = 21.5 kg (from Equation 2)			
F	Pb_{indoor} (kg) = D – E	--	19.1	28.3
G	Percentage of Biosolids-Pb from plumbing = Pb_{indoor} / Total Biosolids-Pb or (F / A)	--	16.2%	24.1%

27

28 *Text S1 References:*


- 29 1. S. Roy, S., M. Tang and M. A. Edwards, Lead release to potable water during the
 30 Flint, Michigan water crisis as revealed by routine biosolids monitoring data,
 31 *Water Res.*, 2019, **160**, 475-483.

32




33

34 **Figure S1.** Monthly cumulative lead, cadmium, nickel, copper and zinc mass in
 35 biosolids (kg) during Jan 2010-Jun 2019. The red and green highlighted areas denotes
 36 biosolids metal levels during the 18 months of the Flint Water Crisis (April 2014-October
 37 2015) and the most recent 18 month time period for which data is available (January
 38 2018-June 2019).



39

40 **Figure S2.** The latest post-FWC results of mean cumulative lead mass in biosolids
 41 (kg/month) and mean %EBL5 for May 2017-Jun 2019 (highlighted) are overlaid on the
 42 grayscale graph from Roy et al. 2019 described thus: Mean cumulative lead mass in
 43 biosolids (kg/month) correlated with mean %EBL5 for four time intervals pre- and during
 44 FWC ($R^2 = 0.99$, $p < 0.05$). Error bars indicate 95% confidence intervals for %EBL5. Due
 45 to water protective measures and a dramatic increase in EBL testing frequency by
 46 Federal Emergency Management Agency (FEMA), the post-FWC result is excluded
 47 from the regression.



48

49 **Figure S3.** Total number and percentage of lead and galvanized iron service lines
 50 replaced in the City of Flint, 2016-19 (Data courtesy: Eric Schwartz [University of
 51 Michigan, Ann Arbor] and Jared Webb [BlueConduit]).

52 **Table S1.** Coefficient of determination (R^2) between plumbing-related metals mass
53 measured in biosolids for January 2018-June 2019.

Metals	R²	p-value
<i>Pb vs. Cu</i>	0.01957	0.5798
<i>Pb vs. Zn</i>	0.007	0.7348
<i>Cu vs. Zn</i>	0.3033	0.0178

54

55 **Table S2.** Reductions in mean WLLs between the July 2016 and August 2017 water
 56 sampling rounds in Flint homes (n=138) with enhanced corrosion control when
 57 approximately 30% (3,624) of lead and galvanized iron pipes had been replaced.

Sample \ Test Round	July 2016	August 2017	% WLL reduction
<i>First Draw</i>	9.6	9	5.8%
<i>Second Draw</i>	3.0	2.1	30.1%
<i>Third Draw</i>	2.4	1.8	23.7%
<i>Composite WLL = 1/2 x first draw + 1/2 x second draw</i>	6.3	5.6	12.0%

58

59

...