

Supporting Information

Trihalomethane, haloacetic acid, haloacetonitrile behavior in electric storage water heaters

Duarte Batista, M. (University of Colorado Boulder); Summers, R.S. (University of Colorado Boulder); Bartrand, T.A. (ESPRI); Yu, Y. (CU/BC); Tolofari, D. (Drexel University; Seidel, C. (Corona Environmental Consulting); Masters, S.V. (University of Colorado Boulder)*

Tracer studies

A tracer solution consisting of a mix of building feed water, previously flushed for 15 minutes and at around 22 °C, and spiked sodium chloride was continuously pumped into the 50-gallon electric water heater for five theoretical tank residence times. The conductivity of the tracer solution was approximately 1.7 mS/cm. Three flow rates (1.5, 2.0 and 2.5 gpm) and two temperature settings (45 °C and 60 °C) were tested. Flow, temperature, and conductivity data were monitored every 2 seconds. Normalized operation time, or throughput, θ , is

$$\theta = t/\tau \quad [S.1]$$

where t is time from the start of tracer injection in minutes,

Normalized conductivity during the fill portion of the experiment was calculated as:

$$C^* = \frac{C - C_0}{C_S - C_0} \quad [S.2]$$

where C is conductivity, C_0 is conductivity in the water heater at the initiation of the tracer study, C_S is the conductivity of the tracer solution in the water heater influent water and C is the conductivity in the water heater effluent with time.

At time zero of the tracer experiment, water temperature within the tank was about 44.5 °C and normalized conductivity was close to zero. As cold water with sodium chloride (initial temperature of 22 °C and conductivity of 1.7 mS/cm) was pumped into the tank, conductivity and temperature gradually changed, and after two theoretical residence times conductivity was equal to the influent value and temperature of the tank effluent dropped to about 37 °C. Temperatures within the tank were not measured. As cold water with tracer is introduced near the bottom of the

tank, it likely displaces hot tank water upwards and the tank behaves as a PFR. After 20 minutes of tank use, which corresponds to the simulated low use pattern in this study, approximately 60% of the tank volume had been displaced with fresh feed water, and the remaining 40% corresponds to hot tank water. As the tank behaved as a PFR at that point in time, it is expected that water quality in tank effluent samples would significantly differ from the feed water quality. After about one tank residence time, temperature difference between feed and tank water decreased, thus allowing mixing to occur, and possibly short-circuiting. At 40 minutes of tank use, which is the duration chosen for the simulated high use pattern in this study, the tank volume had been completely displaced, the temperature difference between influent water and water remaining in the tank decreased and the tank hydraulics approached a mixed reactor, thus causing tank water quality to be similar to the feed water quality (Figure 1). That is, after long periods of use, water in the tank effluent was a mixture of feed water and tank water. For the tanks under high use, the difference in water quality between an early use in the morning and a later use in the afternoon was also assessed. At the beginning of the first use, the hot water within the tank was partially displaced, whereas at the end of the third use, the tank had already been displaced three times throughout the day. Tank hydraulics are likely complex and require additional experimentation or computational fluid dynamic model to understand.

Samples were collected at three locations along the hot water system (Figure 1). The influent sample, or the cold-water supply of the tank, was taken from the feed sample port after the influent line had been flushed for 30 minutes. Flushing the feed line prior to use was intended to reduce the impact of water quality changes between the building entry point and the water heater supply installation on water heater operation and processes. Tank effluent samples were taken towards the end of the daily tank flushing cycle to evaluate initial water quality that remained stagnant in the tank before the actual use. Finally, POU samples were taken directly from the sample port before the showerhead. Samples were collected shortly after the beginning of a use period after water temperature had increased in the pipe connected to the POU sample port. POU samples helped to evaluate water quality consumers would likely be exposed to when using hot water for multiple uses in a house such as taking a shower, handwashing, etc.




Figure S1. Schematic of the tracer study experimental setup.




Figure S2. Normalized conductivity and temperature as a function of throughput in bed volumes.




Figure S3. HAA9 kinetic behavior normalized to the initial HAA9 concentration (n = 36) as a function of bench hold time at free chlorine study site. Estimated travel time within the water distribution system is 24 hours to the lab feed. Average initial DBP concentration was: HAA9 = $28.8 \pm 5.1 \mu\text{g/L}$.




Figure S4. Average normalized HAA9 for all sample locations under the different use patterns in Phase 1 (48 °C) in free chlorine system Boulder, CO (n = 83). Average feed concentration was $25.3 \pm 9.8 \mu\text{g/L}$.




Figure S5. Average normalized HAA9 concentrations for all sample locations under the different use patterns in Phase 2 in free chlorine system Boulder, CO (n = 55). Average feed concentration was $23.1 \pm 2.9 \mu\text{g/L}$. HT = high temperature of 60°C ; LT = low temperature of 45°C




Figure S6. Average normalized DCAA concentrations for all sample locations under the different use patterns in Phase 2 in free chlorine system Boulder, CO (n = 55). Average feed concentration was $10.5 \pm 1.1 \mu\text{g/L}$. HT = high temperature of 60°C ; LT = low temperature of 45°C




Figure S7. Average normalized TCAA concentrations for all sample locations under the different use patterns in Phase 2 in Boulder, CO (n = 55). Average feed concentration was $10.7 \pm 1.1 \mu\text{g/L}$. HT = high temperature of 60°C ; LT = low temperature of 45°C




Figure S8. Average normalized BDCAA concentrations for all sample locations under the different use patterns in Phase 2 in free chlorine system Boulder, CO (n = 55). Average feed concentration was $0.6 \pm 0.2 \mu\text{g/L}$. HT = high temperature of 60°C ; LT = low temperature of 45°C .




Figure S9. Average normalized TTHM and HAA5 for all sample locations under the different use patterns in Phase 1 (45°C) - free chlorine system (n = 83). Average feed TTHM concentration was 26.1 ± 7.4 $\mu\text{g/L}$. Average HAA5 feed concentration was 22.9 ± 9.0 $\mu\text{g/L}$.




Figure S10. Average normalized HAN4 concentrations for all sample locations under the different use patterns in Phase 1 (45°C) in the (a) chlorine system (n = 83) and (b) chloramine system (n=82). Average HAN4 feed concentration in the chlorine system was $1.49 \pm 0.24 \mu\text{g/L}$. Average HAN4 feed concentration in the chloramine system was $2.38 \pm 0.63 \mu\text{g/L}$.

TABLES

Table S1. Sampling schedule and collection. Note: Tanks 3 and 4 = high use; Tanks 1 and 2 = low use.

Time	Activity	Sample collection	
		Day prior to use	Day of use
7:00 AM - 7:30 AM	Feed flush tank = 30 min	Feed sample taken during last 5 min of flush	Feed sample taken during last 5 min of flush
7:30 AM - 8:10 AM	Tank #3 (1 st use) = 40 min		POU high early sample taken at beginning of use (when stable temperature)
8:10 AM - 8:15 AM	Feed flush = 5 min		
8:15 AM - 8:55 AM	Tank #4 (1 st use) = 40 min		POU high early sample taken at beginning of use (when stable temperature)
8:55 AM - 9:00 AM	Feed flush = 5 min		
9:00 AM - 9:20 AM	Tank #1 = 20 min	Tank low use sample taken during last 5 min of use	POU low use sample taken at beginning of use (when stable temperature)
9:20 AM - 9:25 AM	Feed flush = 5 min		
9:25 AM - 9:45 AM	Tank #2 = 20 min	Tank low use sample taken during last 5 min of use	POU low use sample taken at beginning of use (when stable temperature)
11:10 AM - 11:50 AM	Tank #3 (2 nd use) = 40 min		Tank high late sample taken at 5 min before end of use
11:55 AM - 12:35 PM	Tank #4 (2 nd use) = 40 min		Tank high late sample taken at 5 min before end of use
2:50 PM - 3:30 PM	Tank #3 (3 rd use) = 40 min	Tank high early sample taken during last 5 min before end of use	POU high late sample taken at beginning of use (when stable temperature)
3:35 PM - 4:15 PM	Tank #4 (3 rd use) = 40 min	Tank high early sample taken during last 5 min before end of use	POU high late sample taken at beginning of use (when stable temperature)

Table S2. ANOVA for the free chlorine control study DBP formation between the experimental temperatures 48 °C and 60 °C for the reaction times of 3, 16, and 24 hours (n = 93).

	Temp (°C)	Time 1 (hr)	Time 2 (hr)	p < 0.005
TTHM	48	3	16	no
		16	24	no
		3	24	no
	60	3	16	no
		16	24	no
		3	24	no
	48 - 60	3	3	no

	Temp (°C)	Time 1 (hr)	Time 2 (hr)	p < 0.005
	48 - 60	16	16	no
	48 - 60	24	24	no
HAA5	48	3	16	no
		16	24	no
		3	24	no
	60	3	16	no
		16	24	no
		3	24	yes
	48 - 60	3	3	no
	48 - 60	16	16	yes
	48 - 60	24	24	yes
HAA9	48	3	16	no
		16	24	no
		3	24	no
	60	3	16	no
		16	24	no
		3	24	yes
	48 - 60	3	3	no
	48 - 60	16	16	yes
	48 - 60	24	24	yes
DCAA	48	3	16	no
		16	24	no
		3	24	no
	60	3	16	no
		16	24	no
		3	24	no
	48 - 60	3	3	no
	48 - 60	16	16	no
	48 - 60	24	24	no
TCAA	48	3	16	no
		16	24	no
		3	24	no
	60	3	16	yes
		16	24	no
		3	24	yes
	48 - 60	3	3	no
	48 - 60	16	16	yes
	48 - 60	24	24	yes
DBCAA				

	Temp (°C)	Time 1 (hr)	Time 2 (hr)	p < 0.005
	48	3	16	no
		16	24	no
		3	24	no
	60	3	16	yes
		16	24	no
		3	24	yes
	48 - 60	3	3	no
		16	16	yes
		24	24	yes
HAN4	48	3	16	yes
		16	24	no
		3	24	yes
	60	3	16	yes
		16	24	no
		3	24	yes
	48 - 60	3	3	yes
		16	16	no
		24	24	no

Table S3. DBP yields – DBP/TOC (µg DBP/mg TOC) in free chlorine system

	Sample	Avg TTHM/TOC	Std dev	Avg HAA5/TOC	Std dev	Avg HAA9/TOC	Std dev
UFC (Summers et al. 1996)	10 treated surface waters 24 hr, 20 °C	29.4	7.2	18.9*	2.8	-	-
Control Lab temp study - 22 °C (n = 18)	Feed	15.8	-	13.2	-	14.0	-
	3-day and 4-day hold at 22 °C	36.3	3.5	22.7	0.1	23.9	0.1
Control High temperature study - 48 °C and 60 °C (n=93)	Feed	14.7	1.4	12.1	0.8	13.6	1.0
	High temperature samples (3 hr-, 16 hr- and 24 hr-hold at 48 °C and 60 °C)	34.6	6.2	18.5	3.3	20.1	3.4
Combined BLOQ control samples (n = 84)	High temp samples (3 hr-, 16 hr- and 24 hr-hold at 48 °C and 60 °C) and 3-day and 4-day hold at 22 °C	34.8	6.1	18.8	3.4	20.4	3.4
Tank study - Boulder Phase 1 – 45 °C (n=81)	Feed	17.8	5.3	15.7	5.9	17.1	6.0
	All POU samples and tank low use samples	36.7	10.1	23.8	8.0	25.7	8.2
Tank study -	Feed	20.9	6.6	15.1	4.3	16.2	4.6

Boulder Phase 2 – 45 °C and 60 °C (n=55-70)	All POU samples and tank low use samples at 45 °C and 60 °C	42.7	14.0	22.7	6.2	23.8	6.5
---	---	------	------	------	-----	------	-----

Note:

Uniform formation conditions (UFC) tests: (hold time 24 ± 1 h, pH 8.0 ± 0.2 , 24 hour free chlorine residual 1.0 ± 0.4 mg/L and temperature 20 ± 1 °C⁴¹) *Data was based on HAA6/TOC.

Table S4. Average water quality parameters in Phase 1 (45 °C) – free chlorine system Boulder, CO (n = 290).

Use pattern	Sample	Free chlorine (mg/L)		pH		TOC (mg/L)	
		Average	Standard deviation	Average	Standard deviation	Average	Standard deviation
High	Feed	0.8	0.1	7.9	0.1	1.7	0.6
	Tank	0.6	0.1	7.9	0.1	1.7	0.5
High early	POU	BLOQ	-	8.0	0.1	1.7	0.6
	Tank	0.7	0.1	7.9	0.1	1.6	0.5
High late	POU	BLOQ	-	7.9	0.1	1.6	0.5
	Feed	0.8	0.1	7.9	0.1	1.7	0.6
Low	Tank	BLOQ	-	8.4	0.3	1.7	0.5
	POU	BLOQ	-	8.4	0.2	1.4	0.7

Table S5. Average water parameters in Phase 2 - free chlorine system Boulder, CO (n = 200).

Use pattern	Temp (°C)	Sample	Free chlorine (mg/L)		pH		TOC (mg/L)	
			Average	Standard deviation	Average	Standard deviation	Average	Standard deviation
High		Feed	0.7	0.1	7.9	0.1	1.5	0.3
	60	Tank	0.5	0.04	7.9	0.1	1.5	0.3
High early	45	Tank	0.6	0.1	7.9	0.1	1.5	0.3
	60	POU	BLOQ	-	8.1	0.2	1.4	0.3
High late	45	POU	BLOQ	-	8.0	0.2	1.4	0.3
	60	Tank	0.5	0.04	8.0	0.3	1.5	0.4
	45	Tank	0.6	0.04	8.0	0.1	1.5	0.4
	60	POU	BLOQ	-	8.0	0.2	1.5	0.4
	45	POU	BLOQ	-	7.9	0.1	1.5	0.4
		Feed	0.7	0.03	7.9	0.2	1.5	0.3
Low	60	Tank	BLOQ	-	8.3	0.3	1.4	0.3
	45	Tank	BLOQ	-	8.2	0.1	1.5	0.3
	60	POU	BLOQ	-	8.3	0.2	1.4	0.3
	45	POU	BLOQ	-	8.1	0.2	1.4	0.3

Table S6. Average water quality parameters in Phase 1 (48 °C) - chloramination system Philadelphia, PA (n = 273).

Use pattern	Sample	Total chlorine (mg/L)		pH		TOC (mg/L)	
		Average	Standard deviation	Average	Standard deviation	Average	Standard deviation
High	Feed	1.6	0.5	7.5	0.5	1.3	0.3
High early	Tank	1.3	0.5	7.4	0.5	1.3	0.2
	POU	0.8	0.3	7.6	0.4	1.4	0.2
High late	Tank	1.5	0.4	7.5	0.4	1.3	0.2
	POU	1.1	0.3	7.4	0.3	1.3	0.1
Low	Feed	1.7	0.2	7.6	0.6	1.3	0.3
	Tank	1.4	0.4	7.5	0.4	1.2	0.4
	POU	0.9	0.5	7.6	0.4	1.3	0.2

Table S7. Average water quality parameters in Phase 2 - chloramination system Philadelphia, PA (n = 194).

Use pattern	Temp	Sample	Total chlorine (mg/L)		pH		TOC (mg/L)	
			Avg	Std dev	Avg	Std dev	Avg	Std dev
High		Feed	0.3	0.3	6.7	0.4	1.4	0.2
High early	60 °C	Tank	0.4	0.4	6.8	0.3	1.6	0.2
	45 °C	Tank	0.4	0.4	7.0	0.2	1.5	0.2
	60 °C	POU	BLOQ	0.2	7.0	0.2	1.5	0.2
	45 °C	POU	BLOQ	0.2	6.9	0.3	1.4	0.2
High late	60 °C	Tank	0.7	0.6	7.0	0.4	1.4	0.2
	45 °C	Tank	0.7	0.7	7.0	0.3	1.5	0.2
	60 °C	POU	BLOQ	0.2	7.1	0.3	1.4	0.1
	45 °C	POU	0.3	0.3	6.9	0.3	1.5	0.2
Low		Feed	0.3	0.4	6.7	0.3	1.4	0.2
	60 °C	Tank	BLOQ	0.1	6.8	0.2	1.4	0.1
	45 °C	Tank	0.2	0.3	7.1	0.3	1.5	0.1
	60 °C	POU	BLOQ	0.0	7.1	0.3	1.4	0.1
	45 °C	POU	BLOQ	0.1	7.2	0.4	1.4	0.2

Note: Avg – average; Std dev – standard deviation

Table S8. p-values obtained from paired t-tests to evaluate the impact of tank replication on water quality in the free chlorine system (Boulder, CO) and in the chloramination system (Philadelphia, PA) during experimental phase 1 (48 °C).

Boulder - Phase 1 p-values								
Samples		Chlorine Residual	pH	TOC	Norm THM	Norm HAA5	Norm HAA9	Norm HAN4
Tank high early – replicate 1	Tank high early – replicate 2	1.80×10^{-5}	0.584	0.164	0.763	0.185	0.267	0.585
Tank low – replicate 1	Tank low – replicate 2	0.066	0.600	0.797	0.226	0.046	0.057	0.152
POU high early – replicate 1	POU high early – replicate 2	BLOQ	0.054	0.959	0.223	0.495	0.508	0.209
POU low – replicate 1	POU low – replicate 2	BLOQ	0.962	0.880	0.399	0.114	0.213	0.178
Tank high late – replicate 1	Tank high late – replicate 2	0.007	0.338	0.689	0.939	0.571	0.603	0.676
POU high late – replicate 1	POU high late – replicate 2	BLOQ	0.419	0.651	0.272	0.934	0.781	0.484
Samples		Chlorine Residual	pH	TOC	THM	HAA5	HAA9	HAN4
Day 0 feed	Day 1 feed	0.830	0.903	0.833	0.409	0.431	0.493	0.959
Philadelphia - Phase 1 p-values								
Samples		Total Chlorine Residual	pH	TOC	Norm THM	Norm HAA5	Norm HAA9	Norm HAN4
Tank high early – replicate 1	Tank high early – replicate 2	0.116	0.353	0.337	0.085	0.160	0.141	0.056
Tank low – replicate 1	Tank low – replicate 2	0.804	0.809	0.223	0.899	0.175	0.095	0.791
POU high early – replicate 1	POU high early – replicate 2	0.917	0.315	0.475	0.385	0.364	0.064	0.309
POU low – replicate 1	POU low – replicate 2	0.247	0.514	0.374	0.067	0.547	0.762	0.377
Tank high late – replicate 1	Tank high late – replicate 2	0.172	0.603	0.491	0.841	0.882	0.323	0.867
POU high late – replicate 1	POU high late – replicate 2	0.502	0.618	0.761	0.815	0.110	0.217	0.638
Samples		Total Chlorine Residual	pH	TOC	THM	HAA5	HAA9	HAN4
Day 0 feed	Day 1 feed	0.367	0.618	0.467	0.409	0.415	0.350	0.335

Note: Norm - normalized

Table S9. Normalized DBP concentrations, DBP concentration/ DBP concentration of feed (or initial for control), at the POU sample locations and at the point that the chlorine was below the DL in the control studies

Sample point temperature	Time or location	TTHM		HAA5		HAA9		HAN4	
		mean	stdev	mean	stdev	mean	stdev	mean	stdev
control									
22 °C *	72 hr	2.16	-	1.36	-	1.25	-	1.03	
48 °C	3 hr	2.22	0.16	1.48	0.04	1.45	0.04	1.28	0.12
60 °C	3 hr	2.26	0.31	1.43	0.04	1.40	0.06	0.31	0.06
P1 - 45 °C									
High Early	POU	2.16	0.23	1.62	0.15	1.59	0.17	0.18	0.07
High Late	POU	1.69	0.38	1.40	0.25	1.40	0.31	1.19	0.22
Low	POU	2.30	0.16	1.61	0.11	1.58	0.13	0.02	0.04
P2 - 45 °C									
High Early	POU	1.87	0.26	1.53	0.11	1.48	0.11	0.18	0.10
High Late	POU	1.84	0.09	1.47	0.09	1.44	0.09	1.31	0.12
Low	POU	1.98	0.29	1.48	0.10	1.45	0.08	0.06	0.04
P2 - 60 °C									
High Early	POU	1.75	0.30	1.31	0.10	1.27	0.09	0.01	0.01
High Late	POU	1.83	0.09	1.50	0.05	1.46	0.05	0.48	0.14
Low	POU	1.86	0.38	1.19	0.10	1.15	0.08	0.01	0.01

*n=1

Table S10. p-values obtained from **paired t-tests** to evaluate the impact of water use pattern on DBP concentrations during experimental Phase 1 (45 °C)- free chlorine system Boulder, CO.

Boulder - Phase 1 p-values					
Samples		THM	HAA5	HAA9	HAN4
Tank high early	Tank low	1.11×10^{-9}	1.31×10^{-7}	8.51×10^{-7}	5.15×10^{-12}
POU high early	POU low	0.038	0.806	0.714	6.04×10^{-5}
Tank high early	Tank high late	0.256	0.323	0.404	0.163
POU high early	POU high late	0.006	0.026	0.086	5.85×10^{-9}

Table S11. p-values obtained from paired t-tests to evaluate the impact of water use pattern on water quality during Phase 2 - free chlorine system Boulder, CO.

Boulder - Phase 2 p-values					
Samples		THM	HAA5	HAA9	HAN4
Tank high early HT	Tank low HT	0.006	0.245	0.324	5.10×10^{-5}
Tank high early LT	Tank low LT	0.003	0.004	0.004	2.09×10^{-4}
POU high early HT	POU low HT	0.089	0.084	0.106	0.374
POU high early LT	POU low LT	0.016	0.219	0.412	0.016
Tank high early HT	Tank high late HT	0.212	0.325	0.235	0.455
Tank high early LT	Tank high late LT	0.465	0.214	0.261	0.531
POU high early HT	POU high late HT	0.605	0.016	0.022	0.002
POU high early LT	POU high late LT	0.846	0.078	0.041	1.34×10^{-4}

Note: HT = high temperature of 60 °C; LT = low temperature of 45 °C

Table S12. p-values obtained from **paired t-tests** to evaluate the impact of **temperature** on water quality during experimental Phase 2 in free chlorine system Boulder, CO.

Boulder - Phase 2 p-values					
Samples		THM	HAA5	HAA9	HAN4
Tank high early HT	Tank high early LT	0.088	0.035	0.040	0.003
Tank low HT	Tank low LT	0.055	0.013	0.014	0.018
POU high early HT	POU high early LT	0.044	0.012	0.015	0.022
POU low HT	POU low LT	0.061	3.21×10^{-4}	0.001	0.057
Tank high late HT	Tank high late LT	0.164	0.797	0.924	0.203
POU high late HT	POU high late LT	0.909	0.257	0.333	4.62×10^{-5}

Note: HT = high temperature of 60 °C; LT = low temperature of 48 °C

Table S13. Average normalized DBP values (DBP samples/DBP feed) in Phase 1- Philadelphia, PA chloramination system (n = 328). Average feed concentration was TTHM = $22.9 \pm 4.6 \mu\text{g/L}$, HAA5 = $21.8 \pm 6.7 \mu\text{g/L}$ and HAA9 = $28.8 \pm 6.7 \mu\text{g/L}$, HAN4 = $2.4 \pm 0.6 \mu\text{g/L}$.

Use pattern	Sample	Normalized TTHM		Normalized HAA5		Normalized HAA9		Normalized HAN4	
		Avg	Std dev	Avg	Std dev	Avg	Std dev	Avg	Std dev
	Feed	1.00	-	1	-	1	-	1	-
High early	Tank	0.96	0.07	1.00	0.04	0.99	0.03	0.93	0.08
	POU	1.14	0.10	1.12	0.07	1.07	0.07	0.40	0.08
High late	Tank	0.99	0.06	1.02	0.02	1.01	0.03	0.96	0.10
	POU	1.12	0.11	1.07	0.03	1.05	0.04	0.90	0.13
Low	Tank	1.05	0.09	1.06	0.09	1.04	0.08	0.65	0.26
	POU	1.12	0.11	1.12	0.07	1.07	0.07	0.33	0.27

Table S14. p-values obtained from paired t-tests to evaluate the impact of water use pattern on water quality in Philadelphia, PA - chloramination system during Phase 1 (48 °C).

Philadelphia - Phase 1 p-values						
Samples		THM	HAA5	HAA9	HAN4	
Tank high early	Tank low	0.010	0.096	0.138	1.11×10^{-3}	
POU high early	POU low	0.947	0.563	0.556	0.616	
Tank high early	Tank high late	0.180	0.157	0.127	0.495	
POU high early	POU high late	0.697	0.040	0.524	1.48×10^{-6}	

Table S15. Average normalized TTHM, HAA5, HAA9 and HAN4 for all sample locations under the different use patterns during Phase 2 - chloramination system Philadelphia, PA. Average feed concentration were TTHM = 46.7 ± 10.4 µg/L, HAA5 = 20.6 ± 6.6 µg/L, HAA9 = 27.6 ± 8.5 µg/L, and HAN4 = 3.3 ± 0.8 µg/L.

Use pattern	Use time	Sample point	TTHM (µg/L)				HAA5 (µg/L)				HAN4 (µg/L)			
			Low temp 45°C		High temp 60°C		Low temp 45°C		High temp 60°C		Low temp 45°C		High temp 60°C	
			Avg	Std dev	Avg	Std dev	Avg	Std dev	Avg	Std dev	Avg	Std dev	Avg	Std dev
		Feed	1	-	1	-	1	-	1	-	1	-	1	-
High	early	Tank	0.95	0.13	0.96	0.14	1.11	0.21	1.15	0.11	1.15	0.30	1.17	0.31
		POU	1.06	0.14	1.15	0.09	1.22	0.09	1.17	0.16	0.64	0.31	0.31	0.20
	late	Tank	0.95	0.09	0.92	0.18	1.10	0.11	1.01	0.05	0.85	0.24	0.84	0.29
		POU	1.02	0.06	1.02	0.17	1.07	0.08	1.02	0.08	0.80	0.12	0.33	0.13
Low		Tank	1.01	0.05	1.00	0.10	0.89	0.14	0.99	0.12	0.46	0.32	0.34	0.09
		POU	1.13	0.09	1.13	0.11	1.06	0.02	1.03	0.09	0.22	0.16	0.08	0.07

Use pattern	Use time	Sample point	HAA9 (µg/L)			
			Low temp 45°C		High temp 60°C	
			Avg	Std dev	Avg	Std dev
		Feed	1	-	1	-
High	early	Tank	1.06	0.16	1.10	0.03
		POU	1.13	0.02	1.03	0.08
	late	Tank	1.08	0.15	0.99	0.08
		POU	1.04	0.08	0.95	0.06
Low		Tank	0.84	0.12	0.92	0.07
		POU	0.97	0.03	1.01	0.24