

Supplementary Materials

Techno-Economic and Uncertainty Analysis of an Integrated Solar-Hydrogen Energy System for Institutional Decarbonization in Bangladesh

Mohammad Sohel¹, Yasir Arafat^{1*}, Md. Zahid Hasan¹

^{1*} Department of Electrical and Electronic Engineering, International Islamic University
Chittagong, Chattogram-4318, Bangladesh

**Correspondence to:*

ya_eee@iiuc.ac.bd (Dr. Yasir Arafat)

zahidhasan.02@gmail.com (Md. Zahid Hasan)

This Supplementary Materials document contains the following supporting information.

Figures of Content

Figure S1: Diagram of LCA System Boundary (Referee 1 comment no 2 also Referee 2 comment no 2)

Figure S2: EMS flowchart

Figure S3(a): 24 hours EMS dispatch profile for summer, monsoon, and winter cases depicting PV power generation, electrolysis plant operation, hydrogen storage, and grid interfacing.

Figure S3(b): Annual simulation (8,760 hours) of the IIUC solar-hydrogen system for PV-load matching, EMS scheduling, hydrogen storage variation, grid interfacing, and monthly hydrogen production.

Tables of content

Table S1(a): List of Nomenclature

Table S1(b): List of Abbreviations

Table S2: Summary of table S2(a) & S2(b)

Table S2(a): System Boundary Declaration for Life Cycle Assessment (Referee 1 comment no 2 and Referee 2 comment no 2)

Table S2(b): Life Cycle Inventory: All Emission Factors and their Source (Referee 1 comment no 2 and Referee 2 comment no 2)

Table S3: Sensitivity Analysis of LCA: Four Scenarios (Referee 1 comment no 2 and Referee 2 comment no 1)

Table S3(a). Performance Parameters of Components (International Benchmark vs. Bangladesh Tropical Climatic Adjustments):

Table S4: CAPEX/OPEX Localization Scenarios for Bangladesh (Referee 1 comment no 3)

Table S4(a): Summary of LCOH by Scenarios

Table S5: Cost Schedule of Component Replacement and Degradation (Referee 1 comment no 4 and Referee 2 comment no 1)

Table S6: EMS Control Parameters (Referee 1 comment no 5 and Referee 2 comment no 5)

Table S7. Generalized Institutional Hydrogen Implementation Framework (GIHIF): Process for Staged Deployment and Scale-up Criteria in South Asian institutions.

The Figure S1 illustrates the cradle-to-grave system boundary of ISO 14044:2006 for the solar-hydrogen integration plant installed at IIUC, Chittagong, Bangladesh. The specifications of the diagram are given below for drawing.

It responds to Referee 1 comment no 2 also Referee2 comment no 2.




Figure S1: Diagram of LCA System Boundary




Figure S2: EMS Flowchart



Fig. S3(a). 24 hours EMS dispatch profile for summer, monsoon, and winter cases depicting PV power generation, electrolysis plant operation, hydrogen storage, and grid interfacing.




Fig. S3(b). Annual simulation (8,760 hours) of the IIUC solar-hydrogen system for PV-load matching, EMS scheduling, hydrogen storage variation, grid interfacing, and monthly hydrogen production.

Table S1(a): List of nomenclature

Symbol	Definition	Unit
CF_{annual}	Annual capacity factor (19.9%)	%
$CF_{solar-window}$	Solar-window capacity factor (95.3%)	%
$CAPEX_{(alloc)}$	CAPEX allocated to hydrogen production	\$
$C_{(O\&M)}$	Annual operating and maintenance cost	\$/yr
$C_{curt}(t)$	Curtailement penalty cost	\$/kWh
$C_{grid}(t)$	Time-varying grid electricity cost	BDT/kWh
CRF r,n	Capital recovery factor at discount rate r over n years	
D_{month}	Days in a month	Days/month
E_{diesel}	Total energy content of diesel fuel	MJ/month
$E_{el,annual}$	Annual electrical energy consumption for electrolyzer	kWh/yr
$E_{fc,annual}$	Annual fuel cell energy output	kWh
$E_{monthly}$	Monthly electrical energy demand	kWh/month
$E_{solar,gross}$	Gross Solar Energy Generation per month	MWh/month
$E_{solar,net}$	Net Solar Energy Generation per month	MWh/month
E_{spec}	Specific compression energy (2.0 kWh/kg)	kWh/kg
f_d	System derating factor (0.80)	
GWP100	Global warming potential, 100-yr horizon	kg CO ₂ e
h_{op}	Cumulative actual operation hours	h/yr
H_{window}	Solar operating window (1,825 h/yr)	h/yr
LHV_{diesel}	Lower heating value of diesel (36 MJ/L)	MJ/L
LHV_{H_2}	Lower heating value of hydrogen (33.33 kWh/kg)	kWh/kg
\dot{m}_{H_2}	Hydrogen mass production rate or quantity	kg or kg/h
$m_{H_2,annual}$	Annual hydrogen production rate	Kg/yr
$m_{H_2,monthly}$	Monthly hydrogen production rate	Kg/month
$E_{el,daily}$	Daily energy consumption	kWh/day
$m_{H_2,buffer}$	hydrogen buffer mass (700kg)	Kg
$m_{H_2,max}$	Maximum storage capacity (700 kg)	Kg
n	Project lifetime (20 years)	Yr
P_{PV}	Solar plant capacity (6.25 MWp)	MW
P_{comp}	Compressor rated power (175 kW)	kW
$P_{curt}(t)$	Curtailed PV power at timestep t	kW
$P_{el,rated}$	Rated electrolyzer power (5,000 kW)	kW
$P_{el}(t)$	Electrolyzer power consumption at timestep t	kW
$P_{export}(t)$	Grid export power at timestep t	kW
$P_{fc,rated}$	Fuel cell rated power (2,000 kW)	kW
$P_{fc}(t)$	Fuel cell output at timestep t	kW
$P_{grid}(t)$	Grid power exchange at timestep t	kW
P_{load}	Institutional Load	MW
$P_{load}(t)$	Campus electrical demand at timestep t	kW
$P_{PV}(t)$	Net PV generation at timestep t	kW
$P_{el,min}$	Min. electrolyzer dispatch threshold (1,000 kW)	kW
PSH	Peak sun hours (5 h/day)	h/day
$q_{m,refill}$	Compressor mass throughput (87.5 kg/h)	kg/h
R_s	System reliability (98.5%)	%

r	Discount rate / WACC	%
R_{byprod}	Annual co-product revenue (oxygen + grid)	\$/yr
t_{refill}	refill duration (8h)	H
t_{grid}	grid-import hours	H
t_{op}	Daily operating hours	h/day
t_{total}	total hours in a month	H
V_{diesel}	Volume of diesel consumed	L/month
$V_{storage}$	Hydrogen storage volume (30.3 m ³)	m ³
η_{el}	PEM electrolyzer efficiency (80%)	%
η_{fc}	Fuel cell electrical efficiency (50%)	%
ρ_{H_2}	Hydrogen density at 350 bar (23.1 kg/m ³)	kg/m ³
§	Section	

Table S1(b): List of Abbreviations

BDT	Bangladeshi Tk (\$1 = 105 BDT) ¹⁸
BERC	Bangladesh Energy Regulatory Commission
BPDB	Bangladesh Power Development Board
CAPEX	Capital Expenditure
EMS	Energy Management System
FCEV	Fuel Cell Electric Vehicle
GIHIF	Generalized Institutional Hydrogen Implementation Framework
GWP	Global Warming Potential
DICE	Diesel Internal Combustion Engine
ISO	International Organization for Standardization
LAF	Localization adjustment factor for CAPEX
LEL	Lower Explosive limit
LEL	Lower Explosive Limit
LCOH	Levelized Cost of Hydrogen
LCI	Life Cycle Inventory
LHV	Lower Heating Value
NPV	Net present value
NDC	Nationally Determined Contribution
O&M	Operation and Maintenance
PEM	Proton Exchange Membrane
PV	Photovoltaic
SEC	Specific energy consumption
SREDA	Sustainable and Renewable Energy Development Authority, Bangladesh
UDVIA	Unified Dual-Vector Institutional Architecture
WACC	Weighted average cost of capital

Table S2: Summary of table S2(a) & S2(b)

Phase	Description	GHG (tCO ₂ e)	Primary Source
I	Manufacturing: PV (3,125) + Electrolyzer (875) + FC (360) + BoP (400)	4,760	Smith et al. NREL TP-6A20-87372 ⁵¹ ; Elgowainy et al. ANL ⁵²
II-A	Sea freight ~8,000 km (10.1 g CO ₂ e/t-km × 650 t equipment)	53	IMO 4th GHG Study 2020 ⁵³
II-B	On-site civil/electrical installation (5.6 kg CO ₂ e/kW × 13.25 MW equiv.)	74	Smith et al. NREL TP-6A20-87372 ⁵¹
III-A	Compressor grid draw: 175 kW × 8 h/night × 365 × 0.71 kg CO ₂ e/kWh × 20 yr = 7,256 tCO ₂ e; Water treatment: 1,879 m ³ /yr × 0.4 kWh/m ³ × 0.71 × 20 yr = 10.7 tCO ₂ e	7,267	IEA Emissions Factors 2024 ⁵⁵ ; Zhang et al. ³⁵
III-B	FC stack replacement Yr 19 (tropical-adj.): 180 kg CO ₂ e/kW × 2 MW × 0.5 = 180 tCO ₂ e; EMS refresh Yr 10 = 15 tCO ₂ e	195	Elgowainy et al. ⁵³ ; Carmo et al. ⁴
IV	Dismantling (+27.6 tCO ₂ e); Al recovery 85 t × -1.5 kg CO ₂ e/kg = -127.5; Steel recovery 200 t × -0.8 kg CO ₂ e/kg = -160.0	-260 (net credit)	Mendoza Beltran et al. ⁵⁶ , IPCC 2023 ⁵⁴
TOTAL	ISO 14044:2006 Full cradle-to-grave, 4 phases	12,089	Full inventory: Supplementary Tables S2(a)–S2(b)

Table S2 (a): System Boundary Declaration for Life Cycle Assessment

System Boundary Declaration (ISO 14044:2006, Section 4.2.3). Functional Unit: 1kg hydrogen produced and delivered to IIUC campus gate, project duration 20 years, Chittagong, Bangladesh.

It responds to Referee 1 comment no 2 also Referee2 comment no 2.

Phase	Sub Process	Material/Energy Flow	Status	GHG (tCO ₂ e)	ISO §4.3.2 Justification / Primary Source
I	PV mfg.	Si wafers, Al frames, encapsulant, glass	INCL.	3,125	500 kg CO ₂ e/kWp; monocrystalline Si, Smith et al. ⁵¹ ; NREL TP-6A20-87372
I	Electrolyzer mfg.	Ti bipolar plates, Nafion membrane, steel housing	INCL.	875	175 kg CO ₂ e/kW Elgowainy et al. ⁵² ; ANL lifecycle data
I	Fuel cell mfg.	PEM stack, bipolar plates, housing	INCL.	360	180 kg CO ₂ e/kW Elgowainy et al. ⁵²
I	Balance of plant mfg.	Type IV H ₂ vessels, compressor, BOS, piping	INCL.	400	System-level estimate Elgowainy et al. ⁵² ; IRENA ⁴⁰
II-A	Sea freight transport	Container shipping, ~8,000 km Asia to Chittagong, 650 t equip.	INCL.	52.5	IMO 4th GHG Study ⁵³ : 10.1 g CO ₂ e/t-km
II-A	Road freight Transport	Chittagong port to IIUC, 15 km, 650 t	INCL.	0.6	IPCC 2023 ⁵⁴ : 62 g CO ₂ e/t-km

II-B	Civil/Electrical install.	Foundations, mounting, cabling, commissioning	INCL.	74.2	5.6 kg CO ₂ e/kW installed × 13.25 MW eq. Smith et al. ⁵¹
III-A	Compressor grid Operation	175 kW × 8 h/night × 365 × 0.71 kg CO ₂ e/kWh × 20 yr	INCL.	7,256	IEA EF 2024 ⁵⁵ ; BPDB grid carbon intensity 0.71 kg CO ₂ e/kWh
III-A	Water treatment Operation	1,879 m ³ /yr × 0.4 kWh/m ³ × 0.71 kg CO ₂ e/kWh × 20 yr	INCL.	10.7	Zhang et al. ³⁵ ; 0.4 kWh/m ³ RO+DI energy intensity
III-B	FC stack repl. Maintenance	Year 19 (tropical-adjusted); 180 kg CO ₂ e/kW × 2 MW × 0.5	INCL.	180	Elgowainy et al. ⁵² ; Wang et al. ²⁸ (tropical adj.)
III-B	EMS hardware Maintenance	Year 10 refresh; electronics manufacturing	INCL.	15	Industry estimate; electronics MFG intensity
III-B	PEM membrane Maintenance	Lifetime 52,000 h (tropical adj.) = 28.5 yr beyond project	EXCL.	0	Beyond 20-yr boundary ISO 14044 §4.3.2; Carmo et al. ⁴
IV	Dismantling	Equipment disassembly and transport to recycling (200 km)	INCL.	27.6	IPCC 2023 ⁵⁴ : 30 kg CO ₂ e/t demolition + road transport
IV	Al recovery	85 t Al frames × -1,500 g CO ₂ e/kg net credit	INCL.	-127.5	Mendoza Beltran et al. ⁵⁶ : secondary Al credit
IV	Steel recovery	200 t structural steel × -800 g CO ₂ e/kg net credit	INCL.	-160	Mendoza Beltran et al. ⁵⁶ : secondary steel (EAF route)
EXCL	Admin. infra.	Fencing, CCTV, site office, access roads	EXCL.		<0.3% total mass; ISO 14044 §4.3.2 cut-off rule
EXCL	Staff transport	Maintenance personnel commute	EXCL.		<0.2% operational GHG; §4.3.2 cut-off
EXCL	Minor consumables	Gaskets, O-rings, sensor modules, lubricants	EXCL.		Each <0.1% of total; §4.3.2 cut-off
EXCL	N ₂ purge gas	Single-event commissioning purge	EXCL.		<0.05% total; §4.3.2 cut-off
TOTAL 4 Phases			ISO 14044:2006 COMPLIANT		12,089 tCO₂e total 604 tCO₂e/yr annualized 8.17-yr carbon payback

Table S2(b): Life Cycle Inventory: All Emission Factors and Their Sources

Parameter / Component	EF Value	Unit	Year	Source and Applicability Notes
PV module manufacturing (mono-Si, utility scale)	500	kg CO ₂ e/kWp	2024	Smith et al. NREL TP-6A20-87372 ⁵¹ ; US utility-scale; conservative for Chinese-origin modules
PEM electrolyzer (stack + BoP manufacturing)	175	kg CO ₂ e/kW	2022	Elgowainy et al. ANL ⁵² ; Ti plates, Nafion, steel housing, assembly
PEM fuel cell system (stationary PEM)	180	kg CO ₂ e/kW	2022	Elgowainy et al. ANL ⁵² ; PEM stationary; stack + power electronics
Balance of plant (storage, compression, BOS)	400	tCO ₂ e (system)	2022	Elgowainy et al. ⁵² ; Type IV vessels (CF + HDPE) + diaphragm compressor
Bangladesh electricity grid (2023–2024)	0.71	kg CO ₂ e/kWh	2024	IEA Emissions Factors 2024 ⁵⁵ ; grid mix: gas 64%, coal 25%, other 11%

Diesel fuel combustion (automotive diesel)	2.68	kg CO ₂ /L	2023	IPCC 2023 Refinement ⁵⁴ ; Tier 2; biogenic CO ₂ = 0
Sea freight (container ship, Panamax)	10.1	g CO ₂ e/t-km	2020	IMO Fourth GHG Study 2020 ⁵³ ; Asia–Bangladesh route
Road freight (heavy goods vehicle, diesel, >32 t)	62	g CO ₂ e/t-km	2023	IPCC 2023 ⁵⁴ ; gross vehicle weight basis
On-site civil/electrical installation	5.6	kg CO ₂ e/kW installed	2024	Smith et al. NREL ⁵¹ ; South Asian construction cost index applied
Ultrapure water treatment (RO + DI for PEM feed)	0.40	kWh/m ³	2020	Zhang et al. ³⁵ ; reverse osmosis + deionization energy intensity
Al frame recovery (secondary Al production credit)	-1.50	kg CO ₂ e/kg Al	2020	Mendoza Beltran et al. ⁵⁶ ; primary vs. secondary smelting differential
Structural steel recovery (EAF route)	-0.80	kg CO ₂ e/kg steel	2020	Mendoza Beltran et al. ⁵⁶ ; electric arc furnace recycling credit
Generic demolition/dismantling (heavy industrial equip.)	30	kg CO ₂ e/t	2023	IPCC 2023 ⁵⁴ ; conservative estimate for mixed industrial equipment
PV module degradation South Asian tropical climate	0.65	%/yr output loss	2021	Rahman et al. ⁴⁷ ; field data from 14 South Asian institutional PV sites

Table S3: Sensitivity Analysis of LCA: Four Scenarios

All four scenarios validate carbon payback in the 20 years of project lifetime. Grid decarbonization scenario validates that system environmental performance is structurally improving as decarbonization progresses for Bangladesh’s grid.

It responds to Referee 1 comment no 2 also Referee2 comment no 1

Metric	Base Case (ISO 14044)	Tropical Accelerated (-35% PEM life)	Extreme (40,000h PEM; +15% degradation)	Grid 50% Decarbonized (0.355 kgCO₂e/kWh)
Total lifecycle embodied GHG (tCO₂e)	12,089	12,089	12,614	8,461
Annualized lifecycle GHG (tCO₂e/yr)	604	604	631	423
Annual avoided emissions (tCO₂e/yr)	1,480	1,480	1,480	1,480
Net annual GHG reduction (tCO₂e/yr)	876	876	849	1,057
Carbon payback period (years)	8.17	8.17	8.52	5.72
Within 20-yr project life?	YES	YES	YES	YES
Net 20-yr lifecycle benefit (tCO₂e)	17,520	17,520	16,980	21,140
Lifecycle emission reduction efficiency	59.2%	59.2%	57.4%	71.4%
LCOH impact (vs. base) \$/kg	—	\$0.00/kg	\$0.04/kg	-\$0.12/kg

Table S3(a). Performance Parameters of Components (International Benchmark vs. Bangladesh Tropical Climatic Adjustments):

Parameter	International Baseline	Bangladesh Tropical Adj.	Adjustment Basis	LCOH Impact (\$/kg)
PEM Electrolyzer Stack Lifetime	80,000 h (~43.8 yr at 1,825 h/yr)	52,000 h (~28.5 year) beyond project life	Carmo et al. ⁴ : -35% at >85% RH, >30°C; Islam et al. ³⁰ field validation	\$0.00 base case
PEM Fuel Cell Stack Lifetime	50,000 h (~98.6 yr at 507.5 h/yr)	35,000 h (tropical adj.) 19 years replacement	Wang et al. ⁴⁵ : -30% high humidity cycling; Wilberforce et al. ⁴⁶	+\$0.006/kg
PV Module Degradation Rate	0.55%/yr (global average)	0.65%/yr (+18% tropical soiling + UV)	Rahman et al. ⁴⁷ : 0.62–0.68%/yr at 14 South Asian sites	+\$0.19/kg
Electrolyzer Efficiency under High T (>35°C ambient)	80% LHV baseline	78.5% at >35°C (-0.1%/°C above 25°C threshold)	Carmo et al. ⁴ ; Barbir ⁶ : PEM temperature coefficient	Captured in ±3% Monte Carlo σ
Type IV Vessel Inspection Interval	5-year standard	3-year (increased frequency)	ISO 19880-1:2020 ³³ : seal aging acceleration under high humidity	Reflected in O&M cost

Table S4: CAPEX/OPEX Localization Scenarios for Bangladesh

International benchmark costs based on peer reviewed and institutional studies (2023–2024). The Localization Adjustment Factor (LAF) is reflective of Bangladesh import duties (NBR 2023), logistics, local labor rate variations, and foreign exchange risks.

Three cost scenarios × two WACC scenarios = Six LCOH scenarios

It responds to Referee 1 comment 3.

Cost Component	International Baseline (\$/unit)	Moderate LAF +15% (\$/unit)	Conservative LAF +25% (\$/unit)	Import Duty (% NBR)	Source
PEM electrolyzer (stack + BoP)	\$1,400/kW	\$1,610/kW	\$1,750/kW	15–20%	²
Solar PV modules (mono-Si)	\$680/kWp	\$782/kWp	\$850/kWp	15%	³⁹
PV inverters & power electronics	\$90/kWp	\$104/kWp	\$113/kWp	15%	³⁹
PV mounting + BOS	\$75/kWp	\$86/kWp	\$94/kWp	10%	³⁹
PEM fuel cell system (2 MW)	\$850/kW	\$978/kW	\$1,063/kW	15%	^{27,28}
Type IV H ₂ storage (350 bar)	\$650/kg capacity	\$748/kg capacity	\$813/kg capacity	25%	^{25,40}
Diaphragm compressor (175 kW)	\$1,200/kW	\$1,380/kW	\$1,500//kW	20%	²⁵
Grid interface + power conditioning	\$120/kW	\$138/kW	\$150/kW	15%	³²
EMS hardware + SCADA	\$85/kW	\$98/kW	\$106/kW	10%	²⁹
Civil works +	\$420/kW	\$399/kW	\$378//kW	-5%	Local

installation (local labour)				(savings)	estimate
EPC and commissioning	8% of CAPEX	8% of CAPEX	8% of CAPEX	N/A	Industry std.
TOTAL CAPEX (\$ million)	\$16.90M	\$19.44M	\$21.13M	—	Calculated

Table 4(a): Summary of LCOH by Scenarios (concessional rates and PV degradation included for all scenarios):

Scenario	WACC	Total CAPEX (\$M)	LCOH (\$/kg)	NPV (\$M)	Payback (yr)	vs. 2030 Target
International Baseline (LAF=1.00)	8%	\$16.90	\$5.50	-7.23	25.56	Non-viable
International Baseline (LAF=1.00)	4%	\$16.90	\$3.09	-0.23	14.84	Near target
Moderate Local Premium (LAF=+15%)	8%	\$19.44	\$5.89	-8.91	28.14	Non-viable
Moderate Local Premium (LAF=+15%)	4%	\$19.44	\$3.33	-1.89	16.38	Near target
Conservative Local Premium (LAF=+25%)	8%	\$21.13	\$6.38	-10.21	30.42	Non-viable
Conservative Local Premium (LAF=+25%)	4%	\$21.13	\$3.74	-3.52	17.95	Approaching

With 8% WACC, the project is economically non-viable under ALL 6 localization options. With 4% WACC (concessional finance), LCOH is comparable to or close to the 2030 target under ALL 6 localization options. The financing cost, rather than the localization option, determines the project's viability ^{3, 22, 23, 41, 50}.

Table S5: Cost Schedule of Component Replacement and Degradation

It responds to Referee 1 comment no 4 and Referee 2 comment no 1

Component	Nominal Life (h)	Trop. Life (h)	Repl. Year (Base)	Repl. Year (Trop.)	Nominal Cost (\$)	PV 8% WACC (\$)	LCOH Impact (\$/kg)	LCA GHG (tCO _{2e})
PEM electrolyzer membrane	80,000	52,000	Year 43.8 (beyond project)	Year 28.5 (beyond project)	437,500	N/A	\$0.00 base	437.5 (extreme sensitivity only)
PEM membrane extreme (40,000h)	40,000	26,000	Year 21.9 (marginal)	Year 14.2 (Year 14)	437,500	\$80,200	\$0.04	437.5 tCO _{2e}
PEM fuel cell stack (2 MW)	50,000	35,000	Year 50 (nominal)	Year 19 (conservative)	180,000	\$23,800	\$0.006	180 tCO _{2e}
EMS hardware refresh	~10 yr	~10 yr	Year 10	Year 10	35,000	\$16,200	\$0.001	15 tCO _{2e}

Diaphragm compressor	~60,000h	~48,000 h	Year 20.5	Year 16.4	85,000	\$19,600	\$0.003	~10 tCO _{2e}
PV degradation (-0.65%/yr tropical)	Continuous	Continuous	Yr 1–20 continuous	Year 1–20 (accelerated)	Output loss not capital cost	-3.6% H ₂ production	\$0.19/kg	N/A (no manufacturing GHG)
TOTAL IMPACT BASE CASE (8% WACC)				Revised LCOH:	\$5.50 ± 0.70/kg (8% WACC)	\$3.09 ± 0.52/kg (4% WACC)		

Table S6: EMS Control Parameters

It responds to Referee 1 comment no 5 and Referee 2 comment no 5

Parameter	Symbol	Value	Unit	Source	Response Triggered
FUEL CELL DISPATCH (Level 1)					
FC minimum dispatch threshold	$P_{fc,min}$	200	kW (10%)	Wang et al. ²⁸ ; Jiao et al. ²⁷	Grid import preferred below threshold
FC rated power	$P_{fc,rated}$	2,000	kW	Section 2.6 design	Full back up: covers peak campus demand
Grid-outage detection delay	t_{detect}	200	ms	IEEE Std 1547-2018 ³²	EMS switches to island mode; FC dispatch
ELECTROLYZER DISPATCH (Level 2)					
Min. electrolyzer activation threshold	$P_{el,min}$	1,000	kW (20% rated)	Carmo et al. ⁴ ; Barbir ⁶	No dispatch if P_surplus < 1,000 kW; export surplus to grid
Rated electrolyzer power	$P_{el,rated}$	5,000	kW	Section 2.4.1 design	Full production: 120 kg H ₂ /hr
Ramp-up rate limit	dP/dt_{up}	500	kW/min	Barbir ⁶ ; Schmidt et al. ⁵	Prevents transient overvoltage on grid interface
Ramp-down rate limit	dP/dt_{down}	750	kW/min	Barbir ⁶ ; Schmidt et al. ⁵	Controlled shutdown; prevents membrane damage
Cold-start warm up	t_{warmup}	5	min	Schmidt et al. ⁵	No H ₂ production

period					during warm-up; grid covers load
HYDROGEN STORAGE (Level 3)					
Emergency reserve minimum	$m_{H_2,min}$	100	kg (14.3%)	1-day cold-season demand buffer	FC dispatch triggered; grid import if FC unavailable
Maximum storage capacity	$m_{H_2,max}$	700	kg (100%)	Type IV vessel 350 bar ^{25,26}	Electrolyzer curtailed; surplus PV exported to grid
Low-storage alert threshold	$m_{H_2,alert}$	200	kg (28.6%)	2-day cold-season buffer	Predictive alert; increase electrolyzer next solar window
Overnight refill target	$m_{H_2,target}$	700	kg (100%)	Section 2.5 design	Compressor at 87.5 kg/hr; 20:00–04:00 off-peak schedule
GRID INTERACTION (Level 4)					
Max. grid export limit	$P_{export,max}$	500	kW	Assumed BPDB DG limit ³²	Residual PV above 500 kW curtailed
Peak tariff period (BPDB)	t_{peak}	17:00–23:00	Local time	BPDB Retail Tariff 2023 ²⁰	Grid import cost ×2; FC preferred
Off-peak tariff period	$t_{offpeak}$	23:00–17:00	Local time	BPDB Retail Tariff 2023 ²⁰	Compressor operation scheduled
Grid import demand limit	$P_{grid,max}$	1,500	kW	IIUC connection capacity	Prevents demand charge penalty
Grid-outage Island mode trigger	t_{outage}	>4 hr	BPDB profile	BPDB Annual Report ²¹	Suspend export; FC + PV serve load autonomously
Off-peak compression cost saving	ΔC_{comp}	42%	vs. daytime op.	BPDB tariff differential ²⁰	Night-time scheduling reduces compression energy cost
SAFETY (All Levels Continuous Monitoring)					
H ₂ leak detection alarm threshold	$C_{H_2,alarm}$	10% LEL	% of LEL	ISO 19880-1:2020 ³¹	Emergency shutdown; ventilation; control room

					alert
High pressure alarm (storage)	$P_{storage,max}$	385 bar	bar (110% rated)	ASME Section VIII ³³	Compressor shutdown; pressure relief check
Electrolyzer over-temperature shutdown	$T_{el,max}$	75	°C stack	Carmo et al. ⁴ ; tropical adj.	Forced cooling; pause production 10 min
Compressor max. operating pressure	$P_{comp,max}$	420 bar	bar (120% rated)	ISO 19880-1:2020 ³¹	Compressor trip; pressure relief valve actuation

Table S7. Generalized Institutional Hydrogen Implementation Framework (GIHIF): Process for Staged Deployment and Scale-up Criteria in South Asian institutions.

Constraint	IIUC-Specific Assessment	Quantitative Impact	Mitigation Strategy
Load shedding 2–4 hr/day	BPDB documented peak demand periods ²¹	Requires +40% H ₂ buffer storage (700→980 kg) for 99.5% reliability	Phased storage expansion; island mode EMS (Section 2.1.1 Level 4)
Land availability	IIUC campus: ~120 ha; 6.25 MWp requires ~6–7 ha (rooftop + ground)	~5% campus area; IIUC has sufficient open land per site survey	Rooftop-first strategy reduces ground footprint
Local maintenance capacity	No certified H ₂ technicians currently in Chittagong region ²¹	O&M cost premium: +20–30% for 1st 5 years until local skills develop	OEM service contracts (years 1–5); BUET/KUET training partnership
Monsoon irradiance variability	June–September: 3.2–4.1 kWh/m ² /day vs 5.0 annual average ^{35,36}	Monthly H ₂ production drops to 480–520 kg/day; storage buffer critical	700 kg storage provides 1.2-day monsoon autonomy; validated in Table III
Water supply reliability	Ultrapure water: 9 L/kg H ₂ = 1,879 m ³ /yr required	Chittagong municipal supply: 98% reliability; CWASA meter data	200 m ³ rainwater harvesting tank as backup; reduces OPEX \$3,600/yr